

**COMMERCE COMMISSION**

**Handbook for Optimised  
Deprival Valuation of  
System Fixed Assets of  
Electricity Lines Businesses**

**30 August 2004**



**COMMERCE COMMISSION**



# CONTENTS

<b>ABBREVIATIONS USED IN THE HANDBOOK.....</b>	<b>3</b>
<b>PREFACE.....</b>	<b>5</b>
<b>PART ONE: INTRODUCTION.....</b>	<b>7</b>
<i>The Optimised Deprival Valuation Methodology.....</i>	<i>7</i>
<i>The ODV Method as Applied in this Handbook.....</i>	<i>8</i>
<i>Materiality.....</i>	<i>9</i>
<b>PART TWO: PRACTICAL AND MANDATORY VALUATION PROCEDURES.....</b>	<b>10</b>
<b>ASSESSMENT OF REPLACEMENT COST.....</b>	<b>10</b>
<i>Preparation of a Valuation Asset Register.....</i>	<i>10</i>
<i>Assets to be Included in the ODV Valuation.....</i>	<i>11</i>
<i>Estimating Asset Quantities and Ages.....</i>	<i>12</i>
<i>Determination of Replacement Cost.....</i>	<i>12</i>
<b>OPTIMISATION.....</b>	<b>13</b>
<i>Introduction.....</i>	<i>13</i>
<i>Constraints on Optimisation.....</i>	<i>14</i>
<i>The Process of Optimisation.....</i>	<i>15</i>
<i>Future Load Growth.....</i>	<i>15</i>
<i>Quality of Supply.....</i>	<i>16</i>
<i>Excluding Stranded Assets.....</i>	<i>17</i>
<i>Optimising System Configuration.....</i>	<i>17</i>
<i>Optimising Network Capacity.....</i>	<i>18</i>
<i>Optimising Network Engineering.....</i>	<i>18</i>
<i>Optimising Network Equipment Spares.....</i>	<i>18</i>
<i>Determining the Optimised Replacement Cost.....</i>	<i>18</i>
<b>DEPRECIATION.....</b>	<b>19</b>
<i>Approach to Depreciation.....</i>	<i>19</i>
<i>Determining Asset Total Lives.....</i>	<i>19</i>
<i>Determining Asset Remaining Lives.....</i>	<i>19</i>
<i>Refurbishment.....</i>	<i>20</i>
<i>Minimum Residual Life.....</i>	<i>20</i>
<i>Determining the Depreciated Replacement Cost.....</i>	<i>20</i>
<i>Determining the Optimised Depreciated Replacement Cost (ODRC).....</i>	<i>20</i>
<b>ECONOMIC VALUE.....</b>	<b>20</b>
<b>ODV.....</b>	<b>22</b>
<b>ODV VALUATION REPORT.....</b>	<b>22</b>
<b>APPENDIX A: VALUING ASSETS AND STANDARD ASSET REPLACEMENT COSTS AND LIVES ...</b>	<b>25</b>
<i>Standard Replacement Costs.....</i>	<i>25</i>
<i>Asset Types.....</i>	<i>26</i>
<i>Standard Asset Lives.....</i>	<i>30</i>
<i>Refurbishment.....</i>	<i>31</i>
<i>Lives for Particular Asset Types.....</i>	<i>32</i>
<i>Distribution ELBs: Standard Replacement Costs and Asset Lives.....</i>	<i>33</i>
<i>Transpower: Standard Replacement Costs and Asset Lives.....</i>	<i>38</i>
<b>APPENDIX B: OPTIMISATION.....</b>	<b>52</b>
<i>Introduction.....</i>	<i>52</i>
<i>Optimisation of Network Configuration.....</i>	<i>52</i>
<i>Optimisation of Network Capacity and Network Engineering.....</i>	<i>55</i>



## ABBREVIATIONS USED IN THE HANDBOOK

<b><u>Abbreviation</u></b>	<b><u>Term</u></b>
A	Ampere
AC	Alternating Current
ACR	Automatic Circuit Recloser
Act	Commerce Act 1986
Al	Aluminium
CB	Circuit Breaker
CBD	Central Business District
Ccts	Circuits
Commission	Commerce Commission
DB	Double Busbar
DC	Direct Current
DCct	Double Circuit
Dcp	Double circuit pole
Dcst	Double circuit steel tower
Distribution ELBs	ELBs other than Transpower
DRC	Depreciated Replacement Cost
ELB	Large Electricity Lines Business or Large Line Owner or Large Electricity Distributor
EV	Economic Value
GST	Goods and Services Tax
HV	High Voltage (1000 volts and above)
ID	Indoor
IDC	Interest During Construction
IEC	International Electrotechnical Commission (Standard)
km	kilometre
kV	kiloVolt
kVA	kiloVoltAmpere
LPG	Liquefied Petroleum Gas
LV	Low Voltage (below 1000 volts)
m	metre
mm	millimetre
MEA	Modern Equivalent Assets
MVA	MegaVoltAmperes
MW	MegaWatt
OD	Outdoor
ODRC	Optimised Depreciated Replacement Cost
ODV	Optimised Deprival Valuation
O/H	Overhead
OLTC	On Load Tap Changer
ORC	Optimised Replacement Cost
Ph	Phase
PILC	Paper Insulated Lead Covered
PV	Present Value
PVC	Polyvinyl Chloride
RC	Replacement Cost
RL	Remaining Life
SB	Single Busbar
SCADA	System Control And Data Acquisition
Scp	Single circuit pole
Scst	Single circuit steel tower
sqm	square metre
SWER	Single Wire Earth Return

**ABBREVIATIONS USED IN THE HANDBOOK (continued)**

<b><u>Abbreviation</u></b>	<b><u>Term</u></b>
TB	Triple Busbar
TL	Total Life
Transpower	Transpower New Zealand Limited
TV	Tertiary Voltage
U/G	Underground
V	Volt
VT	Voltage Transformer
XLPE	Cross Linked Polyethylene

## PREFACE

### Purpose of the Handbook

- 1 This handbook describing the optimised deprival valuation (ODV) methodology has been published by the Commerce Commission (the Commission) in relation to its responsibilities under Part 4A of the Commerce Act 1986 (the Act). Part 4A of the Act, which came into effect on 8 August 2001, provides for the regulation of large electricity lines businesses, large line owners, and large electricity distributors—collectively, Electricity Lines Businesses (ELBs). Amongst other things, Part 4A includes provisions for a *targeted control regime* in relation to large electricity lines businesses (contained in subpart 1 of Part 4A) and an *information disclosure regime* in relation to the operation and behaviour of large line owners and large electricity distributors (contained in subpart 3 of Part 4A).
- 2 The valuation methodology in this handbook is for valuing the *system fixed assets* of ELBs, as that term is defined by the Commission's information disclosure requirements made from time to time in relation to large line owners and large electricity distributors pursuant to subpart 3 of Part 4A of the Act.
- 3 This handbook supersedes the Commission's *Handbook for Optimised Deprival Valuation of System Fixed Assets of Electricity Lines Businesses*, dated 31 March 2004, and comes into effect on 31 August 2004.

### Coverage of the Handbook

- 4 This handbook covers the valuation of system fixed assets using the ODV methodology for the purposes of Part 4A of the Act. The scope of this handbook does not include the valuation of assets other than system fixed assets that ELBs may own.
- 5 Asset valuation is an important part of the Commission's responsibilities in relation to the regulatory regime for ELBs outlined in Part 4A of the Act. A substantial component of an ELB's asset valuation is the valuation of system fixed assets. The Commission considers that asset valuations are particularly relevant to its following functions under Part 4A:
  - in satisfying the Commission's information disclosure requirements, including disclosure of valuation reports, performance measures and regulatory accounting statements, pursuant to subpart 3 of Part 4A;
  - in resetting the thresholds for the declaration of control, pursuant to subpart 1 of Part 4A;
  - during an inquiry by the Commission following a breach of the thresholds to determine whether or not to make a declaration of control in relation to a large electricity lines business, pursuant to subpart 1 of Part 4A; and
  - when imposing control in relation to a large electricity lines business, pursuant to Part V of the Act.

## **General**

- 6 ELBs encountering problems with this handbook are welcome to discuss issues arising with the Network Performance Group of the Commission.

Network Performance Group  
Business Competition Branch  
Commerce Commission  
WELLINGTON

## **PART ONE: INTRODUCTION**

### **The Optimised Deprival Valuation Methodology**

- 1.1 This handbook details the optimised deprival valuation (ODV) methodology that large electricity lines businesses, large line owners, and large electricity distributors (collectively, ELBs) are required to use when valuing their system fixed assets using the ODV method for the purposes of the regulatory regime under Part 4A of the Commerce Act 1986 (the Act). The term “system fixed assets” is defined by the information disclosure requirements made from time to time by the Commerce Commission (the Commission) in relation to large line owners and large electricity distributors, pursuant to subpart 3 of Part 4A of the Act.
- 1.2 The ODV method measures the economic value of system fixed assets to an ELB on the basis that the ELB operates in an efficient manner that is sustainable over time and is not able to extract monopoly rents. To this end, the ODV method assumes a hypothetical operating environment where the relevant market is contestable and there are no material barriers to entry into that market by an alternative service provider or efficient new entrant. In such a situation the incumbent ELB’s revenue could not exceed the amounts customers would need to pay an efficient new entrant employing a sustainable, cost reflective pricing strategy. In the situation where conventional system fixed assets are economic, a new entrant’s revenue would be determined by the efficient cost of capital required to fund the installation of replacement modern equivalent assets (MEAs) and efficient operating costs. However, in areas where the use of conventional system fixed assets is not economic, a new entrant’s revenue would be determined by the minimum cost of providing an equivalent service not using system fixed assets, which would generally involve an alternative source of energy supply.
- 1.3 In a contestable market a new entrant would endeavour to minimise its costs and would not necessarily replicate the asset base employed by the incumbent ELB. Similarly, if the incumbent ELB were deprived of its assets, and then took action to minimise its loss, it would not necessarily replicate its existing asset base. Under the ODV method, optimisation of an ELB’s existing system fixed assets is therefore necessary to ensure that the valuation asset base is not over designed. The optimisation process must consider system configuration, network capacity and network engineering. Optimisation of the system configuration eliminates existing assets that are not needed to provide the required level of service. Optimisation of the network capacity ensures that any provision in the valuation asset base for future demand growth is prudent, given the need to balance, on the one hand, the long life of system fixed assets, economies of scale and the greater cost of incremental augmentation of the ELB’s network assets with, on the other hand, the planning risks inherent in the installation of capacity over and above the existing requirements. Optimisation of the network engineering ensures that the standard of design and construction of the valuation asset base is consistent across the network and no higher than needed to meet customer service level requirements in the most cost-effective manner.
- 1.4 Consistent with the assumption of a sustainable operation in a contestable market without material barriers to entry, the ODV method requires the replacement cost of existing system fixed assets to be determined as follows:

- (a) Assets that deteriorate in service are to be valued at the replacement costs of MEAs, depreciated to reflect their remaining lives. In this respect, buildings are to be valued at the replacement cost of a building with a standard of construction no higher than that which would be constructed by an efficient new entrant, having regard to the building location and current local authority planning requirements.
  - (b) Land, and any other assets that do not deteriorate in service and have potential alternative uses, are to be valued at market value, as a proxy for their opportunity cost.
  - (c) Easements, and any other assets that do not deteriorate in service and do not have potential alternative uses, are to be valued at historic cost, without depreciation or indexation. In respect of easements, this implies a hypothetical operating environment where a new entrant has access to existing line routes on the same basis as the incumbent ELB. This is consistent with the overriding assumption that there are no material barriers to entry into the transmission and distribution services market.
- 1.5 Where the cost of providing network services using optimised MEAs could be materially higher than the cost of meeting customers' requirements by alternative means, an economic value (EV) test must be applied. In such circumstances the EV of the system fixed assets should be based on the net present value of the minimum charges that customers would pay for an equivalent service using the least cost practical solution. In most cases the least cost practical solution would be to use alternative sources of generation, or supply of energy by an alternative fuel (such as delivered LPG), instead of the supply of electricity through the existing network assets.

### **The ODV Method as Applied in this Handbook**

- 1.6 This handbook sets out the mandatory rules to be applied to determine the valuation of the system fixed assets of an ELB using the ODV method for the purposes of the regulatory regime under Part 4A of the Act. The rules are intended to reflect a practical application of the ODV method based on the design and construction of an ELB's system fixed assets base as typically found in the New Zealand context.
- 1.7 The valuation of an ELB's system fixed assets using the ODV methodology includes the following steps:
- (a) preparation of a valuation asset register;
  - (b) determination of the MEA replacement cost (RC) of the individual assets that make up the existing valuation asset base to determine the RC;
  - (c) optimisation of the existing valuation asset base to determine the optimised replacement cost (ORC);
  - (d) depreciation of the RC on the basis of the remaining lives of the existing assets to determine the depreciated replacement cost (DRC);

- (e) depreciation of the ORC to determine the optimised depreciated replacement cost (ODRC);
  - (f) application of the EV test, to the extent that this is required;
  - (g) determination of the overall ODV, being the aggregation over all assets of the lower of the ODRC and EV for each asset; and
  - (h) preparation of an asset (ODV) valuation report.
- 1.8 This handbook does not require a comprehensive EV test to be applied where an ELB is satisfied that the application of such a test will not lead to an ODV valuation that is materially lower than the ODRC valuation.
- 1.9 All assets and circumstances for which valuation methods and parameters are specifically described in this handbook must be valued in accordance with the specific requirements of the handbook. For system fixed assets and/or circumstances where the valuation method and parameters are not specifically described by this handbook, the valuation shall be undertaken in a manner that is consistent with the overarching ODV methodology as set out in this section (i.e. in Part 1 of the handbook). The valuation approach used for such assets shall be described in the valuation report. The Commission reserves the right to require valuations carried out under this handbook to be revised where it is not satisfied that the valuation complies with the requirements of the handbook.

### **Materiality**

- 1.10 The Commission considers an overall value variance of more than 3% (including any unadjusted variance arising from the economic value assessment part of the ODV methodology) to be material. This level of materiality is to be taken into account by the auditor in their report on the ODV valuation report and by the directors of the ELB in their certification of the ODV valuation report, as may be required from time to time in relation to Part 4A of the Act.
- 1.11 While the level of materiality for the ODV valuation may differ from the level of materiality typically applied by auditors for financial statement reporting purposes under generally accepted accounting practice, the Commission has selected 3% recognising the level of materiality it considers appropriate for regulatory purposes.

## **PART TWO: PRACTICAL AND MANDATORY VALUATION PROCEDURES**

### **ASSESSMENT OF REPLACEMENT COST**

#### **Preparation of a Valuation Asset Register**

- 2.1 An ELB shall maintain comprehensive and accurate databases of its system fixed assets. These databases shall record individual assets to the extent that: (i) the accuracy of the information on an individual asset can be verified by field survey; (ii) each individual asset can be classified into an asset class in accordance with the different asset classes scheduled in Appendix A; and (iii) the age or commissioning date of each individual asset can be separately identified.
- 2.2 The system fixed asset databases shall be updated on an ongoing basis to reflect changes in the makeup of the system fixed assets and to ensure that the databases remain complete and accurate. The updating process must be up to date at the time an ODV valuation is required.
- 2.3 The system fixed asset databases shall be used to compile a valuation asset register that shall form the basis for the ODV valuation of system fixed assets. The valuation asset register should be in a form that facilitates scrutiny and a ready understanding of how it is composed and how the data has been collated from the information in the databases.
- 2.4 The valuation asset register shall divide the individual assets into asset types with the asset types further divided into asset classes, consistent with the breakdown of assets shown in the tables contained in Appendix A. For each asset class, the valuation asset register shall record, as a minimum, the following information:
  - (a) quantity of assets;
  - (b) average age of assets;
  - (c) quantity of assets to which multipliers or other factors have been applied in accordance with the provisions of Appendix A;
  - (d) total RC of assets; and
  - (e) total DRC of assets.
- 2.5 It is recognised that some system fixed assets might not currently be individually recorded in the system fixed asset databases and estimations of asset quantities and ages may therefore be necessary for inclusion in the valuation asset register. However, all new system fixed assets are to be recorded in the databases as they are commissioned. In this way the completeness and accuracy of the databases, and the valuation asset register, can be expected to improve over time.

## **Assets to be Included in the ODV Valuation**

- 2.6 Only system fixed assets owned by the ELB or subject to a finance lease are to be included in the reported ODV valuation. System fixed assets are assets that are tangible in nature, have relatively long useful lives, and are used, or intended to be used, for the conveyance or supply of electricity. Where an easement forms an integral part of a network asset, it should be considered to be a system fixed asset and may be included in the ODV valuation. Stores and spares held in stock that can be used in the network in place of existing network assets may be included in the ODV valuation to the extent that the quantities of items included in the valuation are appropriate, considering the historical reliability of the equipment and the number of items installed on the network.
- 2.7 The following assets shall not be included in the ODV valuation:
- (a) office buildings, except where required for the real time operation and control of the distribution or transmission network;
  - (b) depots and workshops;
  - (c) office furniture and equipment;
  - (d) motor vehicles;
  - (e) tools, plant and machinery;
  - (f) works that are under construction;
  - (g) consumer-based meters and load control relays (except transmission revenue meters);
  - (h) non-network related land;
  - (i) non-network related stores and spares;
  - (j) computer systems, except computer systems that are used for real time network operation and control;
  - (k) asset management systems, including geographic information systems, except where such systems are used for real time network operation and control;
  - (l) street lights and poles or other structures used exclusively for the support of streetlights;
  - (m) street light control relays and circuits or other equipment used exclusively for the control of street lights; and
  - (n) assets where the ownership is disputed or unclear.
- 2.8 This handbook covers only the valuation of system fixed assets, using the ODV methodology as described in the handbook. The handbook does not cover the valuation of assets other than system fixed assets that ELBs may own, such as those listed in clause 2.7 above.

## **Estimating Asset Quantities and Ages**

- 2.9 Where the quantities and ages of certain classes of system fixed assets are required to be estimated, ELBs shall use a statistically robust methodology in undertaking the estimations. The valuation report shall identify system fixed assets for which the quantities and ages have been estimated and include details of the methodologies used to derive the estimates.
- 2.10 Estimates of system fixed assets' quantities and ages shall be regularly reviewed to account for the removal of assets from the network and/or the availability of more accurate information.

## **Determination of Replacement Cost**

- 2.11 Individual system fixed assets, including stores and spares, are to be valued using the replacement costs (RCs) of modern equivalent assets (MEAs) that would be installed today to provide the same service potential as the existing assets. The MEA shall not reflect a service potential required by legislative or regulatory changes made since the assets were first built or installed (except where this is inherent in equivalent assets available on the market at the time of valuation) if the existing assets do not yet need to comply with the additional requirements (e.g. where grandfathering provisions apply). The standard replacement costs for MEAs for commonly used system fixed assets (standard assets) are set out in tables contained in Appendix A. Other details regarding the valuation of particular types of system fixed assets are also contained in Appendix A.
- 2.12 Where a standard replacement cost for a system fixed asset is not provided in Appendix A (non-standard asset), the MEA would normally be the asset that: (i) can be purchased or constructed using current technology at the time of the valuation; and (ii) has an equivalent service potential to that of the existing asset to the extent that this is possible using currently available assets; and (iii) has the lowest lifetime cost. Indicators that can be used to determine the service potential of an MEA include:
- (a) number of faults/100km of line/year;
  - (b) voltage complaints/100km of line/year;
  - (c) proven reliability of the technology;
  - (d) functional compliance with operating requirements;
  - (e) electrical losses; and
  - (f) meeting any statutory, environmental and industry safety requirements that existed at the time the existing asset was installed.
- 2.13 Replacement costs for non-standard assets should be determined on the basis that construction occurs around all existing infrastructure and development (other than the asset being valued). Furthermore, replacement costs shall be commensurate with a significant scale of construction rather than with piecemeal additions. As a guide, replacement costs for zone substations, subtransmission circuits and distribution feeders should be determined on the basis that each complete substation, circuit or feeder is constructed as a single project.

- 2.14 Equipment purchase costs for non-standard assets shall be based on costs charged by manufacturers or suppliers operating in a competitive environment. Construction cost estimates should be based on knowledge of the work involved and efficient industry practice with competitive costs, such as would be charged by efficient private contractors operating in a competitive environment. Alternatively, costs may be based on competitive quotes by turnkey private contractors.
- 2.15 The valuation report shall identify each class of non-standard asset that is included in the valuation. It shall also describe the basis for the determination of the MEAs, and the replacement costs and asset lives of such assets. Details of any analysis used to determine the appropriate MEA, including details of relevant indicators and life cycle cost analysis, and the basis for estimating the replacement cost and asset life used for valuation purposes shall also be provided.
- 2.16 Any grants or contributions towards system fixed assets that have been received should be ignored, as it is the deprival value of the assets that is required, not the actual investment.
- 2.17 Aggregating the RCs of the individual system fixed assets will produce the total network RC.

## **OPTIMISATION**

### **Introduction**

- 2.18 Under the deprival approach to asset valuation an optimised network would use the most cost-efficient design that would provide the required service potential. Such a design conceptually could be undertaken using an approach that disregards completely the design and configuration of the existing asset base. Such an approach, which is cost intensive and likely to result in variable and inconsistent outcomes, is not, however, required by the valuation rules mandated in this handbook. The valuation rules in this handbook allow the existing network to be used as the starting point for the valuation. A series of optimisation tests must be systematically applied to the whole network to identify stranded assets, excess capacity and over-engineering. The minimum optimisation tests required to be carried out by ELBs are contained in Appendix B. Where necessary, the network is notionally redesigned to provide an optimised network. The ORC is the undepreciated replacement cost of the optimised network. A general description of the methodology used to optimise the network shall be included in the valuation report.
- 2.19 The most cost-efficient design is the one that minimises the present value of the total costs of the system fixed assets and their use over their standard lives. In undertaking life cycle cost analyses to determine the most efficient design, an ELB may take into account: (i) the capital and operating costs over the life of the asset; (ii) other costs that are incurred by the ELB as a result of the use of the asset<sup>1</sup>; and (iii) the cost of losses to the extent that these are caused by the existing load and the allowed future load growth.

---

<sup>1</sup> An example of such costs is transmission connection charges incurred by a distribution ELB.

Where a life cycle cost analysis is relied upon to avoid the use of an asset with a lower replacement cost in an optimised network, a general description of the analysis and assumptions used should be included in the valuation report.

2.20 Optimisation should be undertaken after the RC of the existing network asset base has been calculated.

2.21 The optimised network should:

- (a) provide a quality of supply similar to that which currently exists, except where this exceeds the ELB's standard quality of supply criteria; and
- (b) have a capacity similar to that of the existing network, except where this exceeds allowed future load growth.

2.22 Optimisation consists of five stages:

- (a) excluding stranded assets;
- (b) optimising the configuration of the network;
- (c) optimising the capacity of elements in the network;
- (d) optimising network engineering; and
- (e) optimising stores and spares.

2.23 The determination of MEAs that would replace existing individual network components is *not* part of the optimisation process. This shall be done prior to calculating the RC and, for most network components, is already reflected in the standard replacement costs contained in Appendix A.

### **Constraints on Optimisation**

2.24 The optimisation process shall be carried out subject to the following constraints:

- (a) the potential level of service of the optimised network shall not exceed that of the existing network, and the performance of any part of the optimised network shall not exceed the ELB's disclosed quality of supply criteria, unless non-standard contracts with customers exist that require the ELB to provide an enhanced quality of supply;
- (b) the location of points of connection to other networks should be assumed to be fixed. However, where a point of connection can be bypassed and replaced with a more cost-efficient network arrangement, then that point of connection shall be deleted for valuation purposes;
- (c) the location and number of connection points to consumers should be assumed fixed;

- (d) the optimised network should only use the voltage levels used on the existing network<sup>2</sup>; and
- (e) the existing geographic boundaries of the ELB's supply area should be assumed to be fixed.

### **The Process of Optimisation**

2.25 Optimisation of the network shall be undertaken on a systematic basis. The optimisation process must examine the existing network and determine whether a more cost-efficient design could meet the required quality of supply criteria throughout the allowed planning period. Optimisation shall be undertaken systematically across the network and shall include, in particular, the following network components:

- (a) points of connection to other networks;
- (b) transmission lines and transmission substations;
- (c) zone substations and primary distribution switching stations;
- (d) subtransmission lines and primary distribution circuits<sup>3</sup>;
- (e) each high voltage distribution feeder. (For the purposes of the valuation rules in this handbook, a feeder includes any circuit of the distribution network, excluding a low voltage circuit, used to directly supply customers or to supply one or more distribution substations feeding the ELB's own low voltage network); and
- (f) the low voltage distribution system.

### **Future Load Growth**

2.26 The maximum capacity of any part of the optimised network shall be determined by the allowed future load growth, which is the maximum forecast load on the relevant part of the network under contingency operating conditions over the allowed planning period. However, in no case shall optimised capacity exceed existing capacity.

2.27 In order to ensure compliance with clause 2.26, ELBs shall disclose in the valuation report both existing loads and the load forecast used as a basis for optimisation. The forecast loads must take into account any potential to reduce peak demand through the application of cost-effective demand-side management practices. As a minimum, existing and forecast loads shall be provided for each grid exit point, each zone substation and each high voltage distribution feeder. Clear justification and a detailed derivation of the load growth forecasts are required. Both the existing maximum demand and the highest forecast maximum demand during the planning period shall be provided.

---

<sup>2</sup> This does not preclude existing equipment being optimised down to a lower standard network voltage. However, there is no requirement to optimise down to a non-standard voltage level.

<sup>3</sup> A primary distribution circuit is a distribution voltage circuit that is used for the transport of electricity but not for the supply of electricity to customers or for the supply of distribution substations that feed an ELB's low voltage network.

Allowances should be made, where possible, for different growth rates in different parts of the network. Existing loads may be estimated where metering is not available.

- 2.28 The load forecast shall include only future electricity loads that can reasonably be expected to be supplied from the ELB's network. A load outside the existing geographic boundaries of an ELB's area of supply shall not be included in the forecast unless a written customer contract to supply the load exists at the time of the valuation.
- 2.29 Distribution ELBs shall disclose in their valuation reports any separately identifiable new load or load increment exceeding either 5% of the ELB's existing maximum demand or 10 MW (whichever is the lower) that is included within the load forecast. Transpower New Zealand Limited (Transpower) shall similarly disclose any separately identifiable new load or increment of an existing load greater than 100 MW that is included within the load forecast. Transpower shall also disclose any situation where the load forecast includes an increase of greater than 20% of the maximum demand of a grid exit point within a two year period.
- 2.30 The planning periods over which future load growth can be allowed for shall not exceed the following:
- (a) for transmission networks (being networks with a voltage above 33 kV), subtransmission lines, zone substations (excluding transformers), primary distribution circuits and points of connection to a transmission network, 15 years;
  - (b) zone substation transformers, 10 years;
  - (c) for high voltage (HV) and low voltage (LV) distribution, and other network assets, 5 years; and
  - (d) for distribution transformers, no future load growth is permitted. Distribution transformers shall be optimised in terms of capacity utilisation, based on current network loadings in accordance with clause B.11.

### **Quality of Supply**

- 2.31 The optimised network shall be designed to supply the existing load, and the allowed future load growth, with a quality of supply that matches the level that currently exists for each part of the network, except where this is greater than the disclosed quality of supply criteria.
- 2.32 An ELB shall disclose in its valuation report the quality of supply criteria that it currently uses as a basis for network design. This should be based on the ELB's analysis of customer requirements and its assessment of network maintenance requirements and costs.
- 2.33 Relevant quality of supply criteria include:
- (a) the degree of security (redundancy) in different circumstances or localities;
  - (b) target reliability indices for different areas of the network (CBD, urban, rural);

- (c) voltage regulation criteria; and
- (d) levels of electrical losses.

- 2.34 The degree of security may be disclosed either in probabilistic or deterministic terms. A deterministic approach could reference the level of in-built redundancy, i.e. as (n) or (n-1) or (n-2) component redundancy. (An (n) security level implies no component redundancy so that if a component fails, then customer supply is lost. An (n-1) security level is one in which customer supply is not interrupted in the event of any single component outage etc.) Irrespective of whether probabilistic or deterministic criteria are used, it is necessary for an ELB to express its degree of security criteria in such a way that the optimisation process is transparent and can be shown to have been applied consistently across all parts of the network.
- 2.35 General security guidelines for the planning of Transpower's network are given in clause B.6. Other quality of supply criteria for Transpower's network should take account of prudent standards and practices followed in overseas jurisdictions, such as those adopted in Australia and the United Kingdom. Furthermore, where decisions of the Electricity Commission and the contractual relationship between Transpower and its connected customers state or imply security criteria, then these will override the general guidelines. For the avoidance of doubt, optimisation of transmission projects that have been approved by the Electricity Commission is not required.
- 2.36 Existing system fixed assets that provide a quality of supply greater than that disclosed by the ELB shall be optimised out, except where the assets are required to meet the ELB's contractual obligations to provide an improved quality of supply to specific customers.

### **Excluding Stranded Assets**

- 2.37 Any system fixed assets not required to supply line services to existing customers, and which could therefore be disconnected, shall be identified and excluded from the optimised network. Such assets are known as stranded assets and should be treated in accordance with clause 2.44.

### **Optimising System Configuration**

- 2.38 Optimisation of the system configuration shall be carried out by considering alternative configurations subject to the constraints on optimisation and in accordance with the relevant criteria relating to the quality of supply declared by the ELB. The optimised configuration is the one that satisfies the relevant optimisation criteria in the most cost-efficient manner.
- 2.39 In the process of optimising the system configuration, certain assets or groups of assets may become excess to requirements and should be valued at nil, while other new assets may need to be notionally brought in. The minimum tests to be carried out by ELBs in optimising the system configuration are set out in Appendix B.

## **Optimising Network Capacity**

- 2.40 After the configuration of the system has been optimised, the elements within that system shall be optimised by considering whether lower capacity, more cost-efficient elements would be adequate. The minimum tests to be carried out by ELBs in optimising the network capacity are set out in Appendix B.
- 2.41 Civil engineering works such as spare ducts, cable tunnels and switchyard bays not currently used shall be optimised out unless they will be required to meet the allowed future load growth. If the future use of such assets is only intended to provide an improved quality of supply, rather than an increase in system capacity, the assets shall be optimised out since the optimised system shall not provide a quality of supply greater than that which currently exists.

## **Optimising Network Engineering**

- 2.42 As part of the process of optimising the network, the engineering of the network shall be examined to confirm that the optimised asset base is not over-engineered, given the required quality of supply criteria. Over-engineering may occur if parts of the existing asset base are engineered to a standard that exceeds the ELB's current practice or if a more cost-efficient engineering arrangement or configuration would be used if the existing assets were replaced. The ELB's design and construction standards, and the standard of engineering applied to its most recent projects should be used as the benchmark for this test. Where a more cost-efficient arrangement would result if the required level of service were provided by applying the ELB's existing engineering standards then the relevant assets shall be replaced by a notional asset arrangement that reflects current practice. The minimum tests to be carried out by ELBs in optimising the network engineering are set out in Appendix B.

## **Optimising Network Equipment Spares**

- 2.43 Network equipment spares may be included in the ODV valuation as long as the spares are suitable replacements for assets installed in the network. However, the quantity of spares in the ODV valuation shall not exceed the reasonable quantity of spares required to meet the ELB's disclosed quality of supply criteria.
- 2.44 Stranded assets may be valued as network spares, subject to the criteria set out in clause 2.43. Stranded assets not required as network spares shall be assigned a zero value for the purposes of calculating the ODV.

## **Determining the Optimised Replacement Cost**

- 2.45 Once the optimised system has been determined, those parts of the optimised network that are different from the existing network shall be re-evaluated. This entails applying the replacement costs of MEAs to the optimised notional network. A schedule of all network optimisations and details of the valuation impact of each optimisation, including details of the assets removed as stranded assets, shall be included in the valuation report.

- 2.46 When assets are notionally brought into the network as a result of the optimisation process, they should be valued at their replacement costs in accordance with the relevant requirements of this handbook to determine the total replacement cost of the system fixed assets.
- 2.47 Aggregating the individual ORCs of the system fixed assets in the optimised system will produce the total ORC for the network.

## DEPRECIATION

### Approach to Depreciation

- 2.48 An asset replacement cost shall be depreciated when the existing asset's remaining service life is less than the total life (TL) that would normally be expected from a new asset. The depreciation effectively recognises the limited remaining life (RL). The MEA replacement cost of an individual asset shall be depreciated according to the RL of the existing asset.
- 2.49 The straight-line method of depreciation shall be used such that the depreciated replacement cost (DRC) of an asset is determined as:

$$\text{DRC} = \text{RC} \times \text{RL/TL}$$

where:

RC	=	Undepreciated replacement cost;
RL	=	Remaining life; and
TL	=	Total life.

The total lives and the remaining lives need to be established for all system fixed assets (except for land and easements, which are not depreciated).

### Determining Asset Total Lives

- 2.50 The standard TLs of MEAs for different asset classes are set out in the tables in Appendix A. The appendix also contains other details regarding the TLs to be used for particular types of assets.

### Determining Asset Remaining Lives

- 2.51 The life of each system fixed asset commences when the asset is first commissioned or, in the case of stores and spares, when the asset was first delivered into store. The basic procedure for determining RLs is to subtract the ages of assets from their TLs. The age of an asset shall be determined either from records establishing the age or, where necessary, from substantive engineering assessments of the age.
- 2.52 Where an asset's commissioning date is unknown, the age of the asset shall be based on the age used for the previous ODV valuation. Reassessment of the date of installation of an asset or a group of assets is allowable only if objective evidence is available to justify

the reassessment. Evidence of a purely subjective nature, even when provided by a technical expert, is insufficient to satisfy the requirements of this clause. The valuation report shall describe in general terms the evidence used as the basis for changing asset installation dates from those used in the previous ODV valuation, except where the change in installation date is due to the replacement of an asset or the replacement of poles on a transmission or distribution line.

- 2.53 Where an asset may be retired early from service because it may become redundant as part of a network development, this should not be taken into account in assessing the RL of that asset. However, when assets of a particular design are routinely replaced before their technical lives expire as part of the evolution of the network, the standard lives of such assets may be reduced for valuation purposes. The reductions applied and the reasons for them shall be recorded in the valuation report.

### **Refurbishment**

- 2.54 Clauses A.36 and A.37 provide procedures for assigning RLs in cases where system fixed assets have been refurbished.

### **Minimum Residual Life**

- 2.55 Assets whose remaining lives are less than three years shall be deemed to have a residual life of three years.

### **Determining the Depreciated Replacement Cost**

- 2.56 Aggregating the DRCs of the individual system fixed assets will produce the total network DRC.

### **Determining the Optimised Depreciated Replacement Cost (ODRC)**

- 2.57 When optimisation leads to an existing system fixed asset being notionally replaced, the replacement asset shall be depreciated for the same proportion of its TL as the existing asset was depreciated. When the optimisation involves groups of assets being reconfigured, the replacement assets shall be depreciated as a group to reflect the RL of the existing group as a proportion of that group's TL, calculated on a weighted-average basis, with the weighting factor being replacement cost.
- 2.58 Aggregating the ODRCs of the individual system fixed assets in the optimised network will produce the total network ODRC.

## **ECONOMIC VALUE**

- 2.59 Economic valuation is an integral part of the ODV method. However, in calculating the ODV in accordance with this handbook, a comprehensive economic value (EV) test only needs to be applied if the ELB considers that the write-down in asset value as a result of the EV analysis on all potentially uneconomic assets would be greater than 1% of the ODRC of all system fixed assets. The total ODRC of the system fixed assets that an ELB considers to be potentially uneconomic as a proportion of the total ODRC of all the

system fixed assets in the network may be used as a guide to determining whether a comprehensive EV test should be applied. Additionally, a previous EV analysis may be used as a guide to whether a comprehensive EV test is required, after taking due account of the impact of any changed circumstances on the relevance of the previous analysis.

2.60 Uneconomic system fixed assets are those that provide a service that could realistically be provided at a lower cost to users of the network by other means. Such assets should be valued at EV rather than ODRC. A comprehensive EV test, if required, shall be applied to all potentially uneconomic network assets in the following manner:

- (a) Determine the least cost method of providing an alternative equivalent service to that provided by the ELB's uneconomic system fixed assets, using technology available at the time of the valuation. In most cases the least cost practical alternative equivalent service would be to use alternative sources of generation, or the supply of energy by an alternative fuel source (such as delivered LPG).
- (b) Determine the total capital and operating cost of providing the alternative service over a period equal to the total economic life of the existing network assets. This may require allowance for cycles of replacement of the alternative assets. Where the existing network asset comprises a group of individual assets with different total lives, the total life of the existing network assets will be the weighted-average total life with the weighting factor being replacement cost.
- (c) Determine the present value (PV) of the operating and maintenance cost of providing the network service using the existing network assets over the total life of the assets. For simplicity, this may be estimated as a percentage of the RC of the existing assets.
- (d) The EV of the potentially uneconomic system fixed assets is the PV of the total costs of providing the equivalent alternative service less the PV of the costs (excluding network capital related costs) of providing delivered energy using existing network assets, discounted at the ELB's weighted-average cost of capital (WACC) and depreciated to reflect the weighted-average remaining life of the existing network assets. However, the EV cannot be negative (i.e. less than zero) under any circumstances. EV can be expressed as:

$$EV = \text{MAX} ((PV1 - PV2) \times RL/TL, 0)$$

where: PV1 = Present value of the total capital and operating costs of the alternative service over the total life of the existing network assets, inclusive of all costs including delivery and retail margins;

PV2 = Present value of the total operating and maintenance costs of the existing network assets over their total life, together with the present value of the cost of electricity inclusive of the cost of transmission and distribution to the potentially uneconomic

system fixed assets, and inclusive of an allowance for electricity retail margins;

RL = Weighted-average remaining life of existing network assets; and

TL = Weighted-average total life of existing network assets.

2.61 Where an ELB does not undertake a comprehensive EV test on any of its network assets in accordance with the provisions of clause 2.59, it shall include in its valuation report a statement stating that: (i) it has reviewed its system fixed asset base and sought to identify assets that may potentially be uneconomic; and (ii) it is satisfied that an EV analysis of these assets would not result in an ODV of its system fixed assets that is materially less than the ODRC of its system fixed assets in accordance with the materiality threshold set out in clause 2.59. The valuation report shall further describe the basis upon which this conclusion was formed.

2.62 Where an ELB conducts a comprehensive EV test to analyse its potentially uneconomic assets in accordance with clause 2.59, the valuation report shall include: (i) a description of the methodology used to identify the potentially uneconomic assets to which an EV test was applied; (ii) a description of the EV test methodology; and (iii) the ODRC and calculated EV of the assets tested, broken down for each geographically separate, non-contiguous network. Detailed EV calculations need not be included.

## **ODV**

2.63 The ODV of an asset is the lower of its EV or ODRC. Where a comprehensive EV test is not applied, the ODV value of an asset is equivalent to its ODRC. Aggregation of the ODVs, whether ODRCs or EVs, of each system fixed asset valued will produce the total value of system fixed assets at ODV.

## **ODV VALUATION REPORT**

2.64 It is important that ODV valuations are transparent. ELBs are therefore required to provide an ODV valuation report. As a general principle, sufficient information should be included in the valuation report to enable stakeholders to independently assess the validity and robustness of the reported valuation of system fixed assets in accordance with this handbook.

2.65 As a minimum, an ODV valuation report shall contain the following information:

- (a) the asset quantities in the valuation asset base, excluding stores and spares. This information shall be broken down into asset classes consistent with the asset classes contained in the tables in Appendix A;
- (b) the RC, ORC, DRC, ODRC and ODV for each asset class and for the valuation asset base as a whole. This information shall be shown separately for each geographically distinct, non-contiguous network. Stores and spares should be

disclosed separately as separate line items and need not be disaggregated into asset classes;

- (c) a description of the method used for the valuation of any assets where the ELB considers that the valuation method is not specifically prescribed by the valuation rules in this handbook (clause 1.9);
- (d) a schedule of asset classes where asset quantities and/or asset ages have been estimated. For each such asset class the valuation report shall describe the methodology used to derive the estimates (clause 2.9);
- (e) a schedule of asset classes and asset quantities to which multipliers or other adjustments have been made to the standard replacement costs given in the tables in Appendix A. In cases where a range of multipliers or other adjustments is allowed, the valuation report shall show the actual multiplier applied and describe the basis for the selection of a particular multiplier or other adjustment within the range (clause A.4);
- (f) a schedule of replacement costs and asset lives used as the basis for valuing non-standard assets where standard replacement costs or asset lives are not provided in Appendix A, and a general description of the basis for determining the replacement costs or lives of those assets. This information shall include, where appropriate, the basis for selection of MEAs and the methodology used to determine the current replacement cost of the MEA (clause 2.15);
- (g) a schedule of asset classes and quantities for which standard asset lives have been extended or reduced in accordance with the provisions of clauses A.32-A.44, together with the actual lives used, and a schedule showing the date of return to service and remaining life applied to individual assets that have been refurbished since the last valuation (clause A.31);
- (h) a general description of the evidence forming the basis for any change in the date of commissioning of assets from that used in the previous ODV valuation, except where this change is due to the replacement of assets (clause 2.52);
- (i) details of assets to which a reduction in standard lives is applied due to routine replacement as part of the evolution of the network (clause 2.53);
- (j) a general description of the methodology used to optimise the network (clause 2.18);
- (k) a general description of the analysis and assumptions used where life cycle cost analysis is relied upon to avoid the use of an asset with a lower replacement cost in an optimised network (clause 2.19)
- (l) the existing loads and the load growth forecast used as a basis for optimisation. This information shall be disaggregated by point of connection, zone substation and high voltage distribution feeder (clause 2.27);

- (m) forecast new loads or load increases required to be separately disclosed in the valuation report (clause 2.29);
- (n) a description of the quality of supply criteria used as the basis for optimisation (clause 2.32);
- (o) a schedule of all network optimisations and details of the valuation impact of each optimisation, including details of the assets removed as stranded assets (clause 2.45);
- (p) the justification for the inclusion of underground circuits in the optimised system fixed assets base (clauses B.7(b), B.9(b), B.12(a));
- (q) details of any separate network segments with non-coincident peak loads where the distribution transformer capacity was optimised separately from the balance of the network or adjustments for transformer redundancy provided for in non-standard customer contracts (clause B.11);
- (r) where an ELB does not undertake a comprehensive EV test on any of its system fixed assets in accordance with the provisions of clause 2.59, (i) a statement stating that it has reviewed its system fixed assets base and identified assets that are potentially uneconomic, and (ii) a statement stating that it is satisfied that an economic valuation of those assets would not have resulted in a material reduction of the ODV of its system fixed assets, and a description of the basis on which that conclusion was formed (clause 2.61); or
- (s) where a comprehensive EV test is undertaken as part of the valuation process, (i) a description of the methodology used to identify the potentially uneconomic system fixed assets to which the comprehensive EV test was applied (ii) a description of the EV test methodology, and (iii) the ODRC and calculated EV of the assets tested, broken down for each geographically separate, non-contiguous network (clause 2.62).

## **APPENDIX A: VALUING ASSETS AND STANDARD ASSET REPLACEMENT COSTS AND LIVES**

A.1 This appendix gives the methodology to be applied in determining the replacement costs and asset lives to be used in the valuation of system fixed assets. The appendix also contains Table A.1 (for distribution ELBs) and Tables A.2–A.8 (for Transpower) which specify the standard replacement costs and asset lives for the purpose of assessing the depreciated replacement costs of system fixed assets.

### **Standard Replacement Costs**

A.2 Standard replacement costs are shown in Table A.1 (for distribution ELBs) and Tables A.2–A.8 (for Transpower). These replacement costs may be varied for valuation purposes only by the application of multipliers and/or other adjustments as provided for in this appendix.

A.3 The values in the tables are based on installed costs of modern equivalent assets (MEAs) and include the following elements:

- (a) costs of materials delivered to store;
- (b) direct labour including indirect costs (ACC, holiday pay, sick leave, training, supervision, etc.) of installation and commissioning;
- (c) transport and plant costs for delivery and erection; and
- (d) on-costs incorporating business administration, design, construction supervision, and project management costs.

The costs of land use consents, easements, and compensation are excluded. Goods & Services Tax (GST) is excluded but other taxes and duties incurred in the construction of the assets are included.

The standard replacement costs assume the standard project and construction conditions described in this handbook and a significant scale of construction, and include expected cost savings through the use of standard manufacturers' specifications, bulk or term purchasing and competitively tendered turnkey contracts. The standard replacement costs are considered to be realistically achievable by an efficient new entrant that is not constrained by past practices and that proactively manages capital works projects with the objective of minimising total cost.

A.4 For equipment used or installed in adverse conditions, multipliers and/or traffic management allowances can be applied to the values specified in the tables, but only subject to conditions as specified in clauses A.9, A.10, A.14, A.15, A.19 and A.20. To ensure appropriate application of the cost multipliers and/or traffic management allowances, a record of their application shall be retained by the ELB. The record should include:

- (a) multipliers and/or allowances used;
- (b) quantity of the item to which each multiplier and/or allowance is applied; and
- (c) the specific conditions justifying the use of the multipliers and/or allowances.

Furthermore, a schedule of asset quantities and asset classes to which multipliers, traffic management allowances and/or other adjustments have been applied shall be included in the ODV valuation report. Where this handbook specifies a range of possible multipliers or allowances, the valuation report shall also show the actual multiplier or allowance applied and describe the basis on which the ELB selected a particular value within the range.

- A.5 Where more than one multiplier is applicable to a particular asset the effect of the multipliers is to be summated, not multiplied. For example, if multipliers of both 1.25 and 1.3 apply to an asset to adjust for specific construction conditions, then the combined multiplier to be applied is 1.55. However, this does not apply to the interest during construction (IDC) factors in Table A.10, which may be applied to the replacement cost after the application of any other relevant multipliers.
- A.6 Where the nature of an asset in service differs from the nature of any assets in the tables, or where a standard replacement cost for an asset is not provided, an engineering assessment of the replacement cost for the asset shall be made in accordance with clauses 2.12-2.14. Calculations and other records relevant to the engineering assessment shall be retained by the ELB.

### **Asset Types**

- A.7 In the following sections, additional information is given in relation to the valuation of certain types of system fixed assets used by ELBs.

#### *Overhead lines*

- A.8 The economic life of pole type lines shall be based on the weighted-average number of wooden and concrete poles on the line. Similarly, the age of the line for valuation purposes should be equal to the average age of the poles on the line at the time of valuation. To comply with this provision, and notwithstanding the requirements of clauses 2.51 and 2.52, the economic life and age of such lines may be adjusted at each valuation. Consistent with the requirements of clauses 2.51 and 2.52, ELBs shall retain objective evidence supporting such adjustments. If records of pole replacements are not available, then the age of the line should be based on the age used for the previous valuation.
- A.9 *Distribution ELBs:* The standard overhead 33kV, 22kV and 11kV line replacement costs in Table A.1 have, except where otherwise indicated, been based on three-phase construction in a rural environment utilising 70-80m spans. For lines of these voltages in other environments, standard replacement costs can be established by applying the following multipliers:

- (a) overhead line urban 1.5 to 1.8 times Table A.1 cost

- |     |                              |                                  |
|-----|------------------------------|----------------------------------|
| (b) | overhead line remote area    | 1.0 to 1.25 times Table A.1 cost |
| (c) | overhead line rugged terrain | 1.2 to 1.3 times Table A.1 cost. |

Remote areas are those which are situated more than 75km from the ELB's, or ELB contractor's, nearest works depot. Rugged terrain includes those areas where normal line construction vehicles and plant cannot be used and where it is necessary to use helicopters, tracked vehicles, boats, or other specialised plant.

Where appropriate, remote area and rugged terrain multipliers may also be applied to the Table A.1 replacement costs for other asset types.

A.10 *Transpower*: The standard overhead line replacement costs for AC transmission lines in Table A.8 have been based on nominal average span lengths of 165m and 375m for pole and tower lines, respectively, in flat rural land with an assumption that the work is carried out 50km from the nearest urban area. There is no adjustment for further remoteness. Replacement costs for overhead lines in Table A.8 in other terrain can be established by applying the following multipliers:

- |     |                                   |                            |
|-----|-----------------------------------|----------------------------|
| (a) | overhead line hilly terrain       | 1.07 times Table A.8 cost  |
| (b) | overhead line mountainous terrain | 1.23 times Table A.8 cost  |
| (c) | overhead line urban terrain       | 1.20 times Table A.8 cost. |

A.11 The standard replacement costs in Table A.1 for circuits of lower voltage erected on higher voltage lines (i.e. underbuilt) have been based on the marginal cost of additional materials and installation.

A.12 Standard replacement costs for special configurations (e.g. composite 33kV/11kV/LV lines and aerial bundled conductor construction) and for construction at other voltages (e.g. 110kV, 66kV) shall be determined in accordance with clause A.6.

#### *Underground Cables*

A.13 The standard underground cable replacement costs in Table A.1 have been based on laying underground cables in suburban areas with developed infrastructure.

A.14 Cables laid in business districts require special consideration, and a multiplier of 1.15 to 2.0 may be applied to the replacement costs in Table A.1. This multiplier takes into account restricted access times, special reticulation requirements and areas requiring substantial reinstatement and/or special backfilling. Business districts can include main arterial roads (generally those with traffic counts exceeding 10,000 vehicles per day) radiating from them where the roading authority sets requirements similar to those in central business district (CBD) areas. The actual multiplier used should take account of the density of development and other relevant factors that impact cable installation costs. It may be appropriate to use different multipliers for cables installed in different areas or for different sections of a cable route.

A.15 For cables laid in rocky ground, a multiplier of 1.5 to 2.0 can be applied to the replacement costs in Table A.1.

- A.16 The replacement cost of double circuit (viz, two) cables in Table A.1, including cables of differing voltages laid together, incorporates the marginal cost of the extra cable and laying in a joint trench. Where more than two cables of the same voltage are laid together the replacement cost should be determined in accordance with this principle and clause A.6.
- A.17 The replacement cost of cables intended to operate at voltages other than 33kV, 22kV, 11kV, LV and submarine cables should be determined in accordance with clause A.6.
- A.18 The standard replacement cost of all 33kV, 22kV and other HV cables should be based on unarmoured cross linked polyethylene (XLPE) cables being the deemed MEA. The replacement cost of LV cables should be based on polyvinyl chloride (PVC) or XLPE unarmoured construction.

### *Traffic Management*

- A.19 The standard replacement costs for overhead lines and cables include the cost of temporary traffic management as normally required for roads with low traffic volumes. However, where extensive traffic management provisions (e.g. the provision of dedicated staff to direct/control traffic) are required by road control authorities, a traffic management allowance may be added to the standard replacement cost, after any other multipliers have been applied, for every kilometre of cable or line route length. The allowances are:

#### Overhead Lines

- |     |  |                |
|-----|--|----------------|
| (a) | Level 1 temporary traffic management requirements <sup>4</sup> | \$800 per km   |
| (b) | Level 2 temporary traffic management requirements              | \$1,500 per km |

#### Underground Cables

- |     |  |                 |
|-----|--|-----------------|
| (c) | Level 1 temporary traffic management requirements                                    | \$6,000 per km  |
| (d) | Level 2 temporary traffic management requirements                                    | \$15,000 per km |
| (e) | Level 2 temporary traffic management requirements with excavation in the carriageway | \$40,000 per km |

For any line or cable route, the traffic management allowance shall be included in the replacement cost of the primary asset only. It shall not be added to the replacement cost of underbuilt overhead lines or to the incremental costs of additional cables installed in a cable trench.

- A.20 A traffic management allowance shall only be applied if the ELB has objective evidence (such as a classification by the road control authority in accordance with section A3 of the Transit Code of Practice for Temporary Traffic Management in New Zealand) that a given level of traffic control would apply to a particular location. Evidence relied on to

---

<sup>4</sup> As defined in the Transit Code of Practice for Temporary Traffic Management in New Zealand.

support the application of traffic management allowances shall be retained by the ELB. Furthermore, the carriageway excavation allowance shall be applied only in situations where no more cost-efficient cable route is available. Any traffic management allowance shall only be applied to the actual length of line or excavation requiring the specified level of traffic control.

#### *Zone Substations*

A.21 The replacement costs for zone substations should be determined in accordance with clause A.6 and should be presented in the asset classes set out in Table A.1 (for distribution ELBs) and Tables A.2 and A.3 (for Transpower).

A.22 The replacement cost of substation buildings should be included as part of the zone substation valuation, but the land should be valued separately.

#### *Distribution Substations*

A.23 Distribution substations should be valued without distribution transformers, but the land should be valued separately. Standard replacement costs for overhead and ground mounted distribution substations are given in Table A.1.

#### *Distribution Transformers*

A.24 Replacement costs for distribution transformers in respect of distribution ELBs are given in Table A.1 for currently available distribution transformer sizes. Replacement costs for distribution transformers in respect of Transpower are given in Table A.4. Where other sizes are in service, the standard replacement cost of the next largest available size should be used for valuation purposes.

#### *Street Lighting*

A.25 Circuits or other field equipment used exclusively for the control of street lights, or the supply of electricity to street lights in areas where LV reticulation is available, shall not be included in the valuation. Where LV reticulation is not available to supply street lights, street light mains owned by the ELB should be valued as a stand-alone two core cable or underbuilt two wire line, using the standard replacement costs given in Table A.1.

#### *System Control Facilities*

A.26 All system control facilities associated with a system control centre should be valued together as a master station. The value of remote units should be incorporated in the value of the appropriate substation.

#### *Communication Facilities*

A.27 Terminal facilities should be valued as a master station. The value of remote units should be incorporated in the value of the appropriate substation.

## *Easements*

A.28 The value to be assigned to easement rights obtained and registered by distribution ELBs against a land title shall, depending on the situation, be either: (i) a nil value reflecting situations where compensatory payments were not made for loss of land use or consequential loss; or (ii) the original cost of purchase (historic cost) of the easements as recorded in the asset register of the ELB. In any case, no depreciation or indexation of easement values shall be applied.

## **Standard Asset Lives**

A.29 Standard total lives for standard assets are given in Table A.1 (for distribution ELBs) and Tables A.2-A.8 (for Transpower). These lives are to be used for the purpose of determining TLs of assets, except as provided for in clause A.31.

A.30 Total lives of assets not listed in Table A.1 (for distribution ELBs) and Tables A.2-A.8 (for Transpower) should be established on a comparable basis with those in the tables. Such lives should not exceed the total lives included in the tables for comparable assets. Assessment of the TL of such assets should include:

- (a) examination of asset service records;
- (b) discussion with maintenance personnel; and
- (c) physical inspection.

A.31 The total lives of assets listed in Table A.1 (for distribution ELBs) and Tables A.2-A.8 (for Transpower) may only be changed from the standard lives given in the tables in accordance with the provisions of clauses A.32-A.44. ELBs shall include in their valuation reports a schedule of the asset classes and quantities affected by a change to standard asset lives together with the actual lives used. Assets whose lives have been extended since the last valuation as a result of refurbishment in accordance with clauses A.36-A.37 shall be itemised individually in a separate schedule showing the date of return to service and the remaining lives applied to each asset.

A.32 TLs less than the standard lives in Table A.1 (for distribution ELBs) and Tables A.2-A.8 (for Transpower) shall be assigned where considered appropriate. In particular, transmission lines operating in a coastal environment are to be given a TL of 35 years. Circumstances where it may be appropriate to shorten the TL of other assets include:

- (a) assets in coastal environments;
- (b) assets subject to particularly high use or high fault levels or showing systematic premature retirement due to failure; and
- (c) assets which have been poorly maintained.

A.33 The TL of certain assets, as specified below, may be extended where specified conditions have been satisfactorily met. These are:

- (a) zone substation transformers (clause A.40)
- (b) indoor 11kV, 22kV and 33kV switchgear (clause A.42)

- (c) distribution transformers and distribution substations (clause A.43)
- (d) transmission lines (clause A.44)

A.34 In order to justify the extension of TLs as provided in clause A.33, the following information, as applicable, shall be retained by the ELB:

- (a) an age profile of the assets of the type or class concerned, showing the original population, survival population in each year and number of failures in each year. These records must demonstrate that the asset type warrants, on average, the application of a life extension; and/or
- (b) information on the standard or specification used in the purchase of the asset or that type or class of asset. The information must demonstrate use of a technology that would warrant the application of a longer life.

A.35 In addition, the following information shall be available, where relevant:

- (a) a maintenance policy statement indicating the nature, scope and regularity of maintenance work carried out on the asset or class of asset since its installation, sufficient to support the claim for a longer life;
- (b) maintenance and test records of the asset (or, where the life extension relates to a type or class of asset, representative records for that type or class of asset) sufficient to demonstrate that the maintenance policies have been applied over the life of the asset; and
- (c) information on the loading applied to the asset or type or class of asset over time, demonstrating circumstances that would warrant a life extension.

## **Refurbishment**

A.36 Refurbishment is classed as work done on the asset (or set of assets) that results in a material extension of its service life beyond its normal TL. This is distinct from maintenance work, which is done to ensure that an asset is able to perform its designated function for its normal TL.

A.37 When an asset has been refurbished, the ELB should assign an RL, effective from the time of refurbishment, but this RL shall not be greater than the standard TL as specified in Table A.1 (for distribution ELBs) and Tables A.2-A8 (for Transpower). The ODRC value of the asset after refurbishment shall be the new optimised replacement cost of an MEA with an equivalent service potential, depreciated to reflect the assigned remaining life. Where an asset is assigned a new RL in accordance with the provisions of this clause, the ELB shall prepare an engineering report detailing the refurbishment work undertaken and the basis for determining the new remaining life. This engineering report shall be retained by the ELB.

## **Lives for Particular Asset Types**

A.38 Additional information in relation to the assessment of lives of certain types of asset is as follows.

### *Overhead Lines*

A.39 Two different sets of life maxima are given in Table A.1; for concrete poles and wooden poles. This is notwithstanding the fact that a single set of standard replacement costs has been given reflecting the MEA asset replacement type.

### *Zone Substation Transformers*

A.40 The standard TL of zone substation transformers is 45 years, as shown in Table A.1. However, in accordance with clauses A.33-A.35, where sound maintenance programmes have been in place over the life of the asset, the standard TL for any such transformers may be extended, but not to more than 60 years. Such an extension assumes a typical urban and commercial load curve and cyclic loading in accordance with IEC 354 and should cover most situations in New Zealand.

A.41 In order to justify an extension to standard TL, the records required under clause A.35 shall, as a minimum, show that: (i) the loads applied to the transformers over their lives have been below the manufacturers' ratings; (ii) that the transformers have been subjected to a maintenance program that includes regular inspection and oil testing; and (iii) any maintenance requirements noted during inspection and testing are addressed in a timely manner.

### *Indoor Distribution Switchgear*

A.42 The standard TL of indoor switchgear is 45 years, as shown in Table A.1. However, in accordance with clauses A.33-A.35, where indoor switchgear is of modern, sealed design and specified to operate without maintenance for an extended number of operations, the standard TL may be extended, but not to more than 55 years.

### *Distribution Transformers and Distribution Substations*

A.43 The standard TL of distribution transformers is to be taken as 45 years, as shown in Table A.1. However, in accordance with clauses A.33-A.35, distribution transformer and distribution substation standard TLs may be extended, but not to more than 55 years. For the application of an extension to the standard TL, the ELB must have a formal maintenance policy and maintenance records consistent with the requirements of clause A.35. These records must, as a minimum, demonstrate that the ELB inspects its distribution transformer and distribution substation assets in accordance with a planned inspection programme, and proactively addresses maintenance problems such as oil leaks and excessive corrosion in a timely manner.

### *Transmission Lines*

A.44 The standard TL of transmission lines is 55 years, as shown in Table A.8. This is the standard TL allowed for transmission lines constructed in areas with normal environmental conditions. In accordance with clauses A.33-A.35, standard TLs for

transmission lines may be extended, but not to more than 70 years, where the transmission lines are in lower than normal corrosive conditions (dry inland).

### Distribution ELBs: Standard Replacement Costs and Asset Lives

A.45 Table A.1 gives standard replacement costs and asset lives that shall be applied by distribution ELBs in valuing their system fixed assets.

**Table A.1: Distribution ELB Standard Replacement Costs and Lives**

Asset Class	Unit	Notes	Standard Value (\$000) a	Standard Life (Years)	
<b>SUBTRANSMISSION</b>					
				<b>Pole Type</b>	
				<b>Concrete</b>	<b>Wood</b>
33 kV Lines – Heavy ( $\geq 150 \text{ mm}^2$ , $\leq 300 \text{ mm}^2$ Al)	km	b	61	60	45
33 kV Lines – Light ( $< 150 \text{ mm}^2$ Al)	km	b	45	60	45
33 kV Lines – DCct Heavy	km	b	96	60	45
33 kV Lines – DCct Light	km	b	72	60	45
				<b>Cable Type</b>	
				<b>XLPE</b>	<b>PILC</b>
33 kV - Cables ( $\leq 240 \text{ mm}^2$ Al)	km	c	175	45	70
33 kV - Cables DCct ( $\leq 240 \text{ mm}^2$ Al)	km	c	280	45	70
Pilot/Communications Ccts O/H	km	b	**	45	
Pilot/Communications Ccts U/G	km	c	**	45	
33 kV Isolation	No.	i, p	9		35
33 kV Surge Arresters (3 phase set)	No.		8		35
<b>ZONE SUBSTATIONS</b>					
Land	No.		-		-
Site Development and Buildings	No.		**		50
Transformers	No.		**		45
33 kV Indoor Switchgear Cubicle	No.	j	50		45
33 kV Bus Section/Coupler Indoor Switchgear	No.	j	55		45
33 kV Outdoor Circuit Breakers	No.		45		40
22/11 kV Indoor Switchgear Cubicle	No.	j	30		45
22/11 kV Outdoor Circuit Breakers	No.		27		40
Incoming Outdoor Switchgear	No.	k	**		40
Transformer Outdoor Switchgear	No.	k	**		40
Feeder Outdoor Switchgear	No.	k	**		40
Bus Section/Coupler Outdoor Switchgear	No.	k	**		40
Incoming Circuit Protection and Controls	No.		**		40
Transformer Protection and Controls	No.		**		40
Feeder Protection and Controls	No.		**		40
Bus Section/Coupler Protection and Controls	No.		**		40
				<b>Pole Type</b>	
				<b>Concrete</b>	<b>Wood</b>
Outdoor Structure if not included above	Lot		**	60	45
SCADA and Communications Equipment	Lot		**		15
Ripple Injection Plant	Lot		**		20
DC Supplies, Batteries and Inverters	Lot		**		20
Other Items			**		40

Asset Class	Unit	Notes	Standard Value (\$000) a	Standard Life (Years)	
<b>DISTRIBUTION LINES</b>				<b>Pole Type</b>	
				<b>Concrete</b>	<b>Wood</b>
22 kV O/H Heavy ( $\geq 150 \text{ mm}^2, \leq 240 \text{ mm}^2 \text{ Al}$ )	km	b	32	60	45
22 kV O/H Medium ( $> 50 \text{ mm}^2, < 150 \text{ mm}^2 \text{ Al}$ )	km	b	29	60	45
22 kV O/H Light ( $\leq 50 \text{ mm}^2 \text{ Al}$ )	km	b	27	60	45
22 kV single phase or SWER lines	km	b	24	60	45
22 kV O/H DCct Heavy	km	b	50	60	45
22 kV O/H DCct Medium	km	b	46	60	45
22 kV O/H DCct Light	km	b	42	60	45
22 kV O/H Underbuilt Heavy	km	b	17	60	45
22 kV O/H Underbuilt Medium	km	b	16	60	45
22 kV O/H Underbuilt Light	km	b	14	60	45
11 kV O/H Heavy ( $\geq 150 \text{ mm}^2, \leq 240 \text{ mm}^2 \text{ Al}$ )	km	b	31	60	45
11 kV O/H Medium ( $> 50 \text{ mm}^2, < 150 \text{ mm}^2 \text{ Al}$ )	km	b	28	60	45
11 kV O/H Light ( $\leq 50 \text{ mm}^2 \text{ Al}$ )	km	b	25	60	45
11 kV single phase or SWER lines	km	b	21	60	45
11 kV O/H DCct Heavy	km	b	46	60	45
11 kV O/H DCct Medium	km	b	42	60	45
11 kV O/H DCct Light	km	b	38	60	45
11 kV O/H Underbuilt Heavy	km	b	15	60	45
11 kV O/H Underbuilt Medium	km	b	14	60	45
11 kV O/H Underbuilt Light	km	b	12	60	45
<b>DISTRIBUTION CABLES</b>				<b>Cable Type</b>	
				<b>XLPE</b>	<b>PILC</b>
22 kV U/G Heavy ( $> 240 \text{ mm}^2, \leq 300 \text{ mm}^2 \text{ Al}$ )	km	c	155	45	70
22 kV U/G Medium ( $> 50 \text{ mm}^2, \leq 240 \text{ mm}^2 \text{ Al}$ )	km	c	118	45	70
22 kV U/G Light ( $\leq 50 \text{ mm}^2 \text{ Al}$ )	km	c	94	45	70
22 kV U/G DCct Heavy	km	c	220	45	70
22 kV U/G DCct Medium	km	c	160	45	70
11 kV U/G Heavy ( $> 240 \text{ mm}^2, \leq 300 \text{ mm}^2 \text{ Al}$ )	km	c	125	45	70
11 kV U/G Medium ( $> 50 \text{ mm}^2, \leq 240 \text{ mm}^2 \text{ Al}$ )	km	c	103	45	70
11 kV U/G Light ( $\leq 50 \text{ mm}^2 \text{ Al}$ )	km	c	81	45	70
11 kV U/G DCct Heavy	km	c	170	45	70
11 kV U/G DCct Medium	km	c	140	45	70
<b>DISTRIBUTION SWITCHGEAR</b>					
22/11 kV Disconnecter 3 ph (Excl Pole)	No.	p	3.5		35
22/11 kV Disconnecter 2 ph (Excl Pole)	No.	p	2.5		35
22/11 kV Load Break Switch (Excl Pole)	No.	p	6.5		35
22/11 kV Dropout Fuse 3 Ph (Excl Pole)	No.		2.5		35
22/11 kV Dropout Fuse 2 Ph (Excl Pole)	No.		2.0		35
22/11 kV Sectionaliser (Excl Pole)	No.	p	18		40
22/11 kV Recloser (Excl Pole)	No.	p	27		40
Voltage Regulator	No.		**		55
Ring Main Unit – 3 Way	No.	p, q	16		40
Extra Oil Switch	No.	p, q	6		40
Extra Fuse Switch	No.	p, q	8		40

<b>Asset Class</b>	<b>Unit</b>	<b>Notes</b>	<b>Standard Value (\$000) a</b>	<b>Standard Life (Years)</b>
<b>DISTRIBUTION TRANSFORMERS</b>				
<b>Pole Mounted, Single/Two Phase, 22/0.4 and 11/0.4 kV, Bushing Terminations</b>				
Up to and including 15 kVA	No.	d	2.6	45
30 kVA	No.	d	3.3	45
50 kVA	No.	d	4	45
75 kVA	No.	d	5	45
100 kVA	No.	d	7	45
<b>Pole Mounted, Three Phase, Bushing Terminations</b>				
<b>22/0.4 kV</b>				
Up to and including 30 kVA	No.	d	6	45
50 kVA	No.	d	8	45
100 kVA	No.	d	10	45
200 kVA	No.	d	15	45
300 kVA	No.	d	18	45
500 kVA	No.	d	23	45
<b>11/0.4 kV</b>				
Up to and including 30 kVA	No.	d	5	45
50 kVA	No.	d	7	45
100 kVA	No.	d	9	45
200 kVA	No.	d	13	45
300 kVA	No.	d	16	45
500 kVA	No.	d	20	45
<b>Ground Mounted, Single/Two Phase, 22/0.4 and 11/0.4 kV, Cable Entry</b>				
<b>22/0.4 kV</b>				
100 kVA	No.	d, q	10	45
200 kVA	No.	d, q	16	45
300 kVA	No.	d, q	18	45
500 kVA	No.	d, q	25	45
750 kVA	No.	d, q	29	45
1,000 kVA	No.	d, q	34	45
1,250 kVA	No.	d, q	46	45
1,500 kVA	No.	d, q	53	45
<b>11/0.4 kV</b>				
100 kVA	No.	d, q	9	45
200 kVA	No.	d, q	14	45
300 kVA	No.	d, q	16	45
500 kVA	No.	d, q	22	45
750 kVA	No.	d, q	26	45
1,000 kVA	No.	d, q	29	45
1,250 kVA	No.	d, q	40	45
1,500 kVA	No.	d, q	46	45

<b>Asset Description</b>	<b>Unit</b>	<b>Notes</b>	<b>Standard Value (\$000) a</b>	<b>Standard Life (Years)</b>	
<b>DISTRIBUTION SUBSTATIONS</b>					
Pole Mounted (50 kVA or less)	No.	e, l	1	45	
Pole Mounted (100 kVA or more)	No.	e, l	2	45	
Ground Mounted (Covered)	No.	f	4	45	
Kiosk (Masonry or block enclosure)	No.	f	11	45	
On Customer's Premises with Feedout	No.		2	45	
<b>LV LINES</b>					
				<b>Pole Type</b>	
				<b>Concrete</b>	<b>Wood</b>
Overhead Heavy 4 wire LV only (> 150 mm <sup>2</sup> Al)	km	g	45	60	45
Overhead Medium 4 wire LV only (≤ 150 mm <sup>2</sup> Al)	km	g	42	60	45
Overhead Light 4 wire LV only (≤ 50 mm <sup>2</sup> Al)	km	g	38	60	45
Overhead Medium 2 wire LV only (> 50 mm <sup>2</sup> ≤ 150 mm <sup>2</sup> Al)	km	g	36	60	45
Overhead Light 2 wire LV only (≤ 50 mm <sup>2</sup> Al)	km	g	30	60	45
Overhead Heavy Underbuilt 4 wire (> 150 mm <sup>2</sup> )	km	g	24	60	45
Overhead Medium Underbuilt 4 wire (≤ 150 mm <sup>2</sup> )	km	g	21	60	45
Overhead Medium Underbuilt 2 wire (> 50 mm <sup>2</sup> ≤ 150 mm <sup>2</sup> ) Al	km	g	17	60	45
Overhead Light Underbuilt 2 wire (≤ 50 mm <sup>2</sup> ) Al	km	g	14	60	45
<b>LV CABLES</b>					
				<b>Cable Type</b>	
				<b>XLPE or PVC</b>	<b>PILC</b>
Underground Heavy - LV Only (>240 mm <sup>2</sup> )	km	g, h	72	45	70
Underground Medium - LV Only (≤ 240 mm <sup>2</sup> )	km	g, h	63	45	70
Underground Heavy - with HV (>240 mm <sup>2</sup> )	km	g, h	40	45	70
Underground Medium - with HV (≤ 240 mm <sup>2</sup> )	km	g, h	32	45	70
Underground street light circuit (own trench)	km	r	30	45	70
Underground street light circuit (HV cable trench)	km	r	12	45	70
<b>Link Pillars</b>					
2 way Link Pillar	No.		2	45	
4 way Link Pillar	No.		4	45	
<b>CUSTOMER SERVICE CONNECTIONS EXCLUDING METERS AND RELAYS</b>					
LV overhead - 1 ph	No.	m	0.07	45	
LV overhead - 3 ph	No.	m	0.18	45	
LV underground - 1 ph shared fuse pillar	No.	n	0.25	45	
Own fuse pillar	No.	n	0.5	45	
LV underground - 3 ph shared fuse pillar	No.	n	0.4	45	
Own fuse pillar	No.	n	0.8	45	
<b>OTHER SYSTEM FIXED ASSETS</b>					
SCADA and Comms (Central Facilities)	Lot	o	**	15	

Notes:

- (a) All values are based on installed costs (excluding GST) for an MEA.
  - (b) Values relate to costs for rural construction.
  - (c) Values are based on costs of underground reticulation for suburban areas with developed infrastructure and average ground conditions.
  - (d) For intermediate sizes value at next size up.
  - (e) Excludes dropout fuses.
  - (f) Includes enclosure and LV frames. Use kiosk only in situations where substation requires more than one LV frame.
  - (g) If detailed records of LV quantities are not available, the quantities used in the valuation should be based on an average length of LV for each size of transformer.
  - (h) Values are based on costs for suburban areas with developed infrastructure.
  - (i) 33 kV isolation equipment includes load break switches, air break switches and links/isolators.
  - (j) Standard indoor circuit breaker complete with one set of protection CTs, disconnectors and earth switches. Excludes protection.
  - (k) This includes disconnectors, earth switches, and buswork required to connect the equipment together. Excludes circuit breaker.
  - (l) This cost includes the conductor from both the HV and LV lines to the transformer terminals, all HV and LV transformer and line connections, the fuse on the LV side of the transformer, transformer earthing and the transformer platform.
  - (m) Connection includes conductor from the LV line to the property boundary, connection from the line to the LV service and all pole top fuses and fuse holders. Does not include road crossings, which may be valued as an equivalent LV line.
  - (n) Connection includes cable from the LV line to the property boundary, connections from the line to the LV cable, a boundary service pillar, all pillar terminations, fuses and fuse holders. This also covers connection to underground cables. The shared fuse pillar costs shall generally be used except where location requires an individual fuse pillar.
  - (o) Any communications equipment required to communicate with remote control switches should be included with this item. This includes transmitters, repeaters and remote terminal units.
  - (p) Any actuator or motor units required to enable a switch to be remotely operated shall have a standard value of \$3,000/unit. This value shall only be included if the switch can be operated remotely at the time of the valuation.
  - (q) The cost of all cable terminations 11 kV or greater have been included in the cost allowed for switchgear or transformer, as appropriate.
  - (r) Includes terminations to 10 street light poles.
- \*\* No standard value assigned.

## Transpower: Standard Replacement Costs and Asset Lives

A.46 The following tables (Tables A.2-A.8) give standard replacement costs and asset lives that shall be applied in valuing Transpower's system fixed assets.

A.47 The standard replacement costs included in the tables are subject to adjustment for seismic factors (for substations) and interest during construction. The adjustment factors are shown in Tables A.9 and A.10, respectively.

### *Substations by Standard Size*

A.48 For valuing establishment and buildings, substations are split into facilities of four standard sizes - Major, Medium, Small and Rural.

**Table A.2: Establishment Building Block Costs**

Type	Description Summary	Standard Value (\$000)	Standard Life (years)
Major	accommodating on average 14x220kV, 19x110kV and 15x33kV or 15x11kV bays, roadways, etc	3,184.75	55
Medium	accommodating on average 8x220kV, or 8x110kV and 10x33kV or 10x11kV bays, roadways, etc.	1,203.07	55
Small	accommodating on average 6x110kV and 15x33kV or 15x11kV bays, roadways, etc	1,072.82	55
Rural	accommodating on average 2x66kV, 6x33kV or 6x11 bays, roadways, etc	973.34	55

### *Substations (Standard sizes) by Indoor/Outdoor*

A.49 For costing buildings at substations, the four standard sizes are further broken down to differentiate between indoor or outdoor facilities.

**Table A.3: Buildings Building Block Costs**

Type	Description Summary	Standard Value (\$000)	Standard Life (years)
Major OD	Facilities associated with outdoor switchyard with on average 14x220kV, 19x110kV and 15x33kV or 15x11kV bays, 155.5sqm control room.	175.91	55
Major ID	Facilities associated with outdoor switchyard with on average 14x220kV, 19x110kV bays and indoor switchgear and control facilities with on average 15x33kV or 15x11kV bays with 155.5sqm control room and 201.6sqm switchgear room	365.81	55

Type	Description Summary	Standard Value (\$000)	Standard Life (years)
Medium OD	Facilities associated with outdoor switchyard with on average 8x220kV or 8x110kV and 10x33kV or 10x11kV bays, 103.7sqm control room	143.30	55
Medium ID	Facilities associated with outdoor switchyard with on average 8x220kV or 8x110kV bays and indoor switchgear and control facilities with on average 10x33kV or 10x11kV bays with 103.7sqm control room and 159.6sqm switchgear room	143.30	55
Small OD	Facilities associated with outdoor switchyard with on average 6x110kV and 10x33kV or 10x11kV bays, 86.4sqm control room	121.65	55
Small ID	Facilities associated with outdoor switchyard with on average 6x110kV bays and indoor switchgear and control facilities with on average 10x33kV or 10x11kV bays with 86.4sqm control room and 159.6sqm switchgear room	286.87	55
Rural OD	Facilities associated with a rural outdoor switchyard with on average 2x66kV and 6x33kV or 6x11kV bays, 69.1sqm control room	112.95	55
Rural ID	Facilities associated with outdoor switchyard with on average 2x66kV bays and indoor switchgear and control facilities with on average 6x33kV or 6x11kV bays with 69.1sqm control room and 109.2sqm switchgear room	244.86	55

### *Transformers*

A.50 Replacement costs for a large number of power transformer options have been provided to cover the range of power transformer sizes and configurations used by Transpower. Generally, costs are provided for power transformers with On-load Tap Changers, except where identified.

**Table A.4: Power Transformer Building Block Costs**

HV	LV	TV/ MVA	Vector	Phase	MVA 3ph	OLTC	Standard Value (\$000)	Standard Life (years)
220	110	11/60	A	3	200	No	2,842.58	55
220	110		A	3	200	Yes	2,535.81	55
220	110	11/60	A	1	200	Yes	1,541.83	55
220	110		A	3	180	Yes	2,372.31	55
220	110	14.5/ 141.5	A	3	141.5	Yes	2,300.44	55
220	110		A	3	120	Yes	2,062.22	55
220	110	11/60	A	3	100	Yes	1,958.86	55
220	110		A	3	100	Yes	1,852.42	55
220	110	11/60	A	1	100	No	1,056.57	55
220	110		A	3	90	Yes	1,907.18	55
220	110	33/30	A	3	70	Yes	1,803.81	55

HV	LV	TV/ MVA	Vector	Phase	MVA 3ph	OLTC	Standard Value (\$000)	Standard Life (years)
220	110	11/30	A	1	65	No	902.01	55
220	110	11/30	A	3	60	Yes	1,752.13	55
220	110	11/30	A	3	50	No	1,489.46	55
220	110	11/30	A	1	50	No	836.11	55
220	66	11/60	S-S	3	200	Yes	3,047.37	55
220	66	11/60	S-S	1	200	Yes	1,643.80	55
220	66	11/60	S-S	3	100	No	2,151.45	55
220	66	11/60	S-S	1	100	No	1,126.35	55
220	66	33/30	S-S	3	70	Yes	1,930.09	55
220	66	11/30	S-S	1	50	No	917.92	55
220	55		TR	1	18	Yes	820.79	55
220	55		TR	1	15	Yes	778.87	55
220	33		S-D	3	200	Yes	3,278.42	55
220	33		S-D	1	200	Yes	1,315.29	55
220	33		S-D	3	150	Yes	2,715.32	55
220	33		S-D	3	120	Yes	2,366.39	55
220	33		S-D	3	100	Yes	2,273.37	55
220	33		S-D	1	100	Yes	1,000.29	55
220	33		S-D	1	63	No	793.15	55
220	33		S-D	3	60	Yes	1,668.55	55
220	33		S-D	3	50	Yes	1,639.87	55
220	33		S-D	1	50	No	723.70	55
220	33		S-D	1	30	No	616.84	55
220	33		S-D	3	30	Yes	1,319.64	55
220	33		S-D	3	25	Yes	1,261.48	55
220	33		S-D	3	20	No	1,155.49	55
220	33		S-D	3	18	Yes	1,180.06	55
220	33		S-D	3	15	Yes	1,145.17	55
220	33		S-D	3	10	Yes	1,017.85	55
220	33		S-D	3	5	No	925.47	55
220	22		S-D	3	50	Yes	1,632.54	55
220	22		S-D	1	50	Yes	744.47	55
220	16	33/60	S-D	1	240	Yes	1,383.60	55
220	11		S-D	3	100	Yes	2,415.16	55
220	11		S-D	3	70	Yes	1,955.02	55
220	11		S-D	3	60	Yes	1,801.64	55
220	11		S-D	3	12	Yes	1,065.42	55
220	11		S-D	3	10	Yes	1,034.75	55
110	66		D-S	3	60	Yes	1,184.96	55
110	66		D-S	3	55	Yes	1,119.64	55
110	66	11/10	A	1	30	No	498.89	55
110	66	11/10	A	1	20	No	456.02	55
110	66	11/10	A	1	15	No	434.58	55
110	50		D-S	3	30	No	835.05	55
110	50		D-S	1	30	No	451.61	55
110	50		D-S	1	20	No	400.28	55
110	50		D-S	1	15	No	374.61	55
110	50		D-S	1	14.1	No	369.99	55
110	50		D-S	3	10	No	663.97	55

HV	LV	TV/ MVA	Vector	Phase	MVA 3ph	OLTC	Standard Value (\$000)	Standard Life (years)
110	50		D-S	1	10	No	348.94	55
110	33		D-S	3	120	Yes	1,803.28	55
110	33		D-S	3	100	Yes	1,628.28	55
110	33		D-S	1	100	Yes	797.40	55
110	33		D-S	3	75	Yes	1,403.33	55
110	33		D-S	3	70	Yes	1,358.33	55
110	33		D-S	3	60	Yes	1,268.35	55
110	33		D-S	3	60	Yes	1,268.35	55
110	33		D-S	1	50	No	555.42	55
110	33		D-S	3	50	No	1,084.92	55
110	33		D-S	3	40	Yes	1,088.38	55
110	33		D-S	1	40	No	512.97	55
110	33		D-S	3	38	No	968.60	55
110	33		D-S	3	35	Yes	1,043.38	55
110	33		D-S	1	30	Yes	477.53	55
110	33	11/10	D-S	1	30	No	487.33	55
110	33		D-S	3	30	Yes	1,033.22	55
110	33	11/10	D-S	3	30	No	1,067.96	55
110	33		D-S	3	28	No	871.67	55
110	33		D-S	1	27.5	No	459.92	55
110	33		D-S	3	25	Yes	953.41	55
110	33		D-S	1	20	No	428.08	55
110	33		D-S	3	20	No	859.65	55
110	33		D-S	3	20	Yes	908.41	55
110	33		D-S	3	18	Yes	890.41	55
110	33		D-S	3	15	Yes	833.57	55
110	33		D-S	1	10	No	389.00	55
110	22		D-S	3	50	Yes	1,193.51	55
110	22		D-S	1	50	Yes	604.07	55
110	22		D-S	3	30	Yes	945.94	55
110	22		D-S	1	30	Yes	449.90	55
110	11		D-S	3	60	Yes	1,322.73	55
110	11		D-S	3	50	Yes	1,201.15	55
110	11	33/20	S-D	3	50	Yes	1,253.74	55
110	11		D-S	3	40	Yes	1,078.51	55
110	11		D-S	1	30	No	449.01	55
110	11		D-S	3	30	Yes	955.85	55
110	11		D-S	1	30	Yes	483.78	55
110	11		D-S	3	28	No	884.29	55
110	11		D-S	1	28	No	441.09	55
110	11		D-S	3	27	Yes	919.07	55
110	11		D-S	1	27	Yes	472.31	55
110	11		D-S	3	25	Yes	894.53	55
110	11		D-S	1	25	Yes	461.26	55
110	11		D-S	3	20	Yes	836.52	55
110	11		D-S	1	20	Yes	433.65	55
110	11		D-S	3	15	Yes	771.89	55
110	11		D-S	3	10	Yes	710.56	55
110	11		D-S	1	10	Yes	396.65	55

HV	LV	TV/ MVA	Vector	Phase	MVA 3ph	OLTC	Standard Value (\$000)	Standard Life (years)
110	11		D-S	1	8	Yes	367.36	55
110	11		D-S	3	7.5	Yes	679.90	55
110	11		D-S	1	7.5	Yes	364.60	55
110	11		D-S	3	5	Yes	649.24	55
110	11		D-S	1	5	Yes	350.79	55
110	11		D-S	1	4.5	No	349.28	55
110	11		D-S	3	4	No	636.19	55
110	11		D-S	3	3	Yes	624.72	55
110	11		D-S	1	2.25	Yes	322.44	55
110	11		D-S	3	1	Yes	597.94	55
66	33		D-S	3	60	Yes	1,113.53	55
66	33		D-S	3	45	Yes	958.40	55
66	33		D-S	3	40	Yes	906.68	55
66	33		D-S	3	20	Yes	699.83	55
66	33		D-S	1	20	Yes	377.70	55
66	33		D-S	3	16	Yes	658.46	55
66	33	11/7.5	A	1	15	No	429.14	55
66	33		D-S	3	15	Yes	648.12	55
66	33		D-S	3	10	Yes	596.41	55
66	33		D-S	3	9	No	537.82	55
66	33		D-S	3	5	Yes	544.69	55
66	33		D-S	1	5	No	260.90	55
66	11		D-S	3	45	Yes	999.11	55
66	11		D-S	3	40	Yes	946.53	55
66	11		D-S	3	30	Yes	841.35	55
66	11		D-S	1	30	Yes	433.23	55
66	11		D-S	3	20	Yes	736.17	55
66	11		D-S	1	20	Yes	366.69	55
66	11		D-S	3	16.5	Yes	699.35	55
66	11		D-S	3	10	Yes	630.99	55
66	11		D-S	1	10	Yes	300.15	55
66	11		D-S	3	5	Yes	578.40	55
66	11		D-S	1	5	Yes	266.88	55
66	11		D-S	1	3.75	No	217.70	55
66	11		D-S	3	3	Yes	557.36	55
66	11		D-S	1	3	Yes	253.57	55
66	11		D-S	3	1	No	361.75	55
66	11		D-S	3	0.5	Yes	531.07	55
50	33		S-S	3	5	No	477.81	55
50	33		S-S	1	5	No	260.90	55
50	11		D-S	1	15	Yes	350.09	55
50	11		D-S	3	7.5	Yes	558.83	55
50	11		D-S	1	7.5	Yes	288.76	55
50	11		D-S	1	5	Yes	268.32	55
50	11		D-S	1	3	No	189.88	55
50	11		D-S	1	2.25	No	219.93	55
50	11		D-S	3	2	Yes	438.30	55
33	11		D-S	3	20	Yes	562.58	55
33	11		D-S	3	15	Yes	540.10	55

HV	LV	TV/ MVA	Vector	Phase	MVA 3ph	OLTC	Standard Value (\$000)	Standard Life (years)
33	11		D-S	3	13	Yes	531.12	55
33	11		D-S	3	10	No	524.19	55
33	11		D-S	1	10	No	286.45	55
33	11		D-S	3	7.5	Yes	506.39	55
33	11		D-S	3	5	Yes	495.15	55
33	11		D-S	3	2.25	No	357.38	55
33	11		D-S	3	2	No	352.00	55
11	11		A	3	4.5	Yes	494.52	55

### *Oil Containment*

Oil containment is costed based upon the capacity of the facility.

**Table A.5: Oil Containment Building Block Costs**

Capacity (m <sup>3</sup> )	Description	Standard Value (\$000)	Standard Life (years)
10	Oil Containment System	68.78	45
15	Oil Containment System	75.24	45
18	Oil Containment System	76.83	45
25	Oil Containment System	80.52	45
30	Oil Containment System	83.16	45
35	Oil Containment System	85.79	45
40	Oil Containment System	88.43	45
45	Oil Containment System	91.07	45
50	Oil Containment System	93.60	45
55	Oil Containment System	96.34	45
60	Oil Containment System	98.98	45
65	Oil Containment System	101.62	45
70	Oil Containment System	104.26	45
75	Oil Containment System	106.90	45
80	Oil Containment System	109.53	45
85	Oil Containment System	112.17	45
90	Oil Containment System	118.46	45
115	Oil Containment System	128.00	45
160	Oil Containment System	149.02	45

Switchgear

**Table A.6: Switchgear Building Block Costs**

kV	Description	CB qty	Bus Type	Out/ In	Standard Value (\$000)	Standard Life (years)
220	1.5 Line Breaker	1	SB	O	947.20	45
220	1.5 Half Breaker	1	-	O	763.64	45
220	1.5 Transformer Breaker	1	SB	O	631.59	45
220	Transmission Line - No Bus	1	-	O	754.35	45
220	Transmission Line - Single Bus	1	SB	O	835.37	45
220	Transmission Line - Double Bus	1	DB	O	985.22	45
220	Transmission Line - Triple Bus	1	TB	O	1,183.52	45
220	Connection Circuit - No Bus	1	-	O	361.78	45
220	Connection Circuit - Single Bus	1	SB	O	442.80	45
220	Connection Circuit - Double Bus	1	DB	O	592.65	45
220	Connection Circuit - Triple Bus	1	TB	O	790.95	45
220	Generator - No Bus	0	-	O	68.23	45
220	Generator - Single Bus	0	SB	O	149.24	45
220	Generator - Double Bus	0	DB	O	299.09	45
220	Generator - Triple Bus	0	TB	O	497.40	45
220	Bus Section	1	SB	O	418.20	45
220	Bus Coupler – Dual Bus	1	DB	O	980.02	45
220	Bus Coupler - Triple Bus	1	TB	O	1,057.88	45
110	Transmission Line - No Bus	1	-	O	403.29	45
110	Transmission Line - Single Bus	1	SB	O	476.75	45

<b>kV</b>	<b>Description</b>	<b>CB qty</b>	<b>Bus Type</b>	<b>Out/ In</b>	<b>Standard Value (\$000)</b>	<b>Standard Life (years)</b>
110	Transmission Line - Double Bus	1	DB	O	668.04	45
110	Connection Circuit - No Bus	1	-	O	251.62	45
110	Connection Circuit - Single Bus	1	SB	O	325.08	45
110	Connection Circuit - Double Bus	1	DB	O	516.37	45
110	Incomer - No Bus	1	-	O	251.62	45
110	Incomer - Single Bus	1	SB	O	325.08	45
110	Incomer - Double Bus	1	DB	O	516.37	45
110	Generator - No Bus	0	-	O	50.55	45
110	Generator - Single Bus	0	SB	O	124.01	45
110	Generator - Double Bus	0	DB	O	315.31	45
110	Bus Section	1	SB	O	283.42	45
110	Bus Coupler	1	DB	O	836.95	45
110	Bus VT		-	-	46.11	45
66	Transmission Line - No Bus	1	-	O	389.79	45
66	Transmission Line - Single Bus	1	SB	O	454.11	45
66	Transmission Line - Double Bus	1	DB	O	630.83	45
66	Connection Circuit - No Bus	1	-	O	245.48	45
66	Connection Circuit - Single Bus	1	SB	O	309.80	45
66	Connection Circuit - Double Bus	1	DB	O	486.52	45
66	Incomer – No Bus	1	-	O	245.48	45
66	Incomer – Single Bus	1	DB	O	309.80	45
66	Incomer – Dual Bus	1	DB	O	486.52	45

<b>kV</b>	<b>Description</b>	<b>CB qty</b>	<b>Bus Type</b>	<b>Out/ In</b>	<b>Standard Value (\$000)</b>	<b>Standard Life (years)</b>
66	Generator – No Bus	0	-	O	48.00	45
66	Generator – Single Bus	0	SB	O	112.32	45
66	Generator – Double Bus	0	DB	O	289.04	45
66	Bus Section	1	SB	O	275.89	45
66	Bus Coupler	1	DB	O	791.92	45
66	Bus VT		-	-	38.96	45
50	Transmission Line – No Bus	1	-	O	386.53	45
50	Transmission Line – Single Bus	1	SB	O	446.23	45
50	Connection Circuit - No Bus	1	-	O	244.78	45
50	Connection Circuit - Single Bus	1	SB	O	304.48	45
50	Incomer – No Bus	1	-	O	244.78	45
50	Incomer – Single Bus	1	SB	O	304.48	45
50	Bus Section	1	SB	O	275.13	45
50	Bus Coupler	1	DB	O	0.00	45
50	Bus VT		-	-	38.96	45
33	OD Feeder – No Bus	1	-	O	221.22	45
33	OD Feeder – Single Bus	1	SB	O	245.40	45
33	OD Feeder – Dual Bus	1	DB	O	283.55	45
33	OD Incomer – No Bus	1	-	O	202.74	45
33	OD Incomer – Single Bus	1	SB	O	223.62	45
33	OD Incomer – Dual Bus	1	DB	O	261.77	45
33	OD Bus Section	1	SB	O	194.96	45
33	OD Bus Coupler	1	DB	O	243.33	45
33	OD Bus VT		-	-	0.00	45
33	Recloser	1	ACR	O	45.21	45
11	OD Feeder - Single Bus	1	SB	O	81.44	45
11	OD Feeder - Dual Bus	1	DB	O	98.66	45
11	OD Incomer - Single Bus	1	SB	O	94.24	45

<b>kV</b>	<b>Description</b>	<b>CB qty</b>	<b>Bus Type</b>	<b>Out/ In</b>	<b>Standard Value (\$000)</b>	<b>Standard Life (years)</b>
11	OD Incomer - Dual Bus	1	DB	O	110.51	45
11	OD Bus Section	1	SB	O	90.05	45
11	OD Bus Coupler	1	DB	O	102.54	45
11	Recloser	1	ACR	O	36.43	45
33	Circuit Breaker - Indoor Bus Coupler	1	DB	I	128.80	45
33	Circuit Breaker - Indoor Bus Section	1	SB	I	99.57	45
33	Circuit Breaker - Indoor Feeder	1	SB	I	86.77	45
33	Circuit Breaker - Indoor Feeder - Double Bus	1	DB	I	127.40	45
33	Circuit Breaker - Indoor Incomer	1	SB	I	92.77	45
33	Circuit Breaker - Indoor Incomer - Double Bus	1	DB	I	131.50	45
22	Circuit Breaker - Indoor Bus Coupler	1	DB	I	120.70	45
22	Circuit Breaker - Indoor Bus Section	1	SB	I	87.65	45
22	Circuit Breaker - Indoor Feeder	1	SB	I	83.25	45
22	Circuit Breaker - Indoor Feeder - Double Bus	1	DB	I	119.90	45
22	Circuit Breaker - Indoor Incomer	1	SB	I	84.45	45
22	Circuit Breaker - Indoor Incomer - Double Bus	1	DB	I	124.20	45
11	Circuit Breaker 500MVA - Indoor Bus Coupler	1	DB	I	107.77	45
11	Circuit Breaker 500MVA - Indoor Bus Section	1	SB	I	71.07	45

<b>kV</b>	<b>Description</b>	<b>CB qty</b>	<b>Bus Type</b>	<b>Out/ In</b>	<b>Standard Value (\$000)</b>	<b>Standard Life (years)</b>
11	Circuit Breaker 500MVA - Indoor Feeder	1	SB	I	69.47	45
11	Circuit Breaker 500MVA - Indoor Feeder - Double Bus	1	DB	I	107.37	45
11	Circuit Breaker 500MVA - Indoor Incomer	1	SB	I	73.47	45
11	Circuit Breaker 500MVA - Indoor Incomer - Double Bus	1	DB	I	110.67	45
11	Circuit Breaker 750MVA - Indoor Bus Coupler	1	DB	I	232.96	45
11	Circuit Breaker 750MVA - Indoor Bus Section	1	SB	I	98.57	45
11	Circuit Breaker 750MVA - Indoor Feeder	1	SB	I	95.57	45
11	Circuit Breaker 750MVA - Indoor Feeder - Double Bus	1	DB	I	195.16	45
11	Circuit Breaker 750MVA - Indoor Incomer	1	SB	I	145.57	45
11	Circuit Breaker 750MVA - Indoor Incomer - Double Bus	1	DB	I	274.96	45

*Reactive Power Plant*

**Table A.7: Reactive Power Plant Building Block Costs**

<b>Description</b>	<b>Standard Value (\$000)</b>	<b>Standard Life (years)</b>
110 kV Two Zone Bus Protection	130.51	15
220 kV Two Zone Bus Protection	130.51	15
66 kV Two Zone Bus Protection	130.51	15
Neutral Earthing Resistor 11kV 12.5 ohms 500A	66.00	45
Neutral Earthing Resistor 22kV 25 ohms 500A	71.00	45
Neutral Earthing Resistor 33kV 37.5 ohms 500A	76.00	45
Neutral Earthing Resistor 17.5kV 2 ohms 300A	66.00	45
Neutral Earthing Resistor 17.5kV 2 ohms 1500A	76.00	45
Neutral Earthing Resistor 17.5kV 2 ohms 3000A	86.00	45
Neutral Earthing Resistor 17.5kV 2 ohms 6400A	96.00	45

*Transmission Lines*

**Table A.8: Transmission Line Building Block Costs**

<b>Voltage (kV)</b>	<b>Config</b>	<b>Rating (A)</b>	<b>Conductor</b>	<b>Temp. (°C)</b>	<b>Standard Value (\$000)</b>	<b>Standard Life (years)<sup>5</sup></b>
11	Scp	220	1/mink	50	36.64	55
33	Dcp	315	1/hyena	50	61.98	55
33	Dcp	360	1/coyote	50	66.21	55
33	Dcp	525	1/wolf	75	74.40	55
33	Scp	220	1/mink	50	37.29	55
33	Scp	315	1/hyena	50	41.09	55
33	Scp	360	1/coyote	50	43.21	55
33	Scp	410	1/hyena	75	41.03	55
33	Scp	525	1/wolf	75	47.36	55
50	Scp	220	1/mink	50	40.00	55
50	Scp	315	1/hyena	50	43.80	55
66	Ddst	315	1/hyena	50	112.14	55
66	Ddst	410	1/hyena	75	114.37	55
66	Ddst	525	1/wolf	75	137.48	55
66	Ddst	640	1/goat	50	170.65	55
66	Ddst	1960	2/zebra	75	318.88	55
66	Dcp	290	1/mink	75	65.92	55
66	Dcp	525	1/wolf	75	90.07	55

<sup>5</sup> Transmission lines are assigned lives according to environmental factors (see clause A.44).

<b>Voltage (kV)</b>	<b>Config</b>	<b>Rating (A)</b>	<b>Conductor</b>	<b>Temp. (°C)</b>	<b>Standard Value (\$000)</b>	<b>Standard Life (years)<sup>5</sup></b>
66	Dcp	640	1/goat	50	115.38	55
66	Scst	315	1/hyena	50	91.61	55
66	Scp	220	1/mink	50	40.84	55
66	Scp	315	1/hyena	50	44.64	55
66	Scp	360	1/coyote	50	46.77	55
66	Scp	410	1/hyena	75	44.28	55
110	Dcst	315	1/hyena	50	123.14	55
110	Dcst	360	1/coyote	50	128.81	55
110	Dcst	410	1/hyena	75	125.92	55
110	Dcst	525	1/wolf	75	141.18	55
110	Dcst	640	1/goat	50	176.57	55
110	Dcst	750	1/zebra	50	194.99	55
110	Dcst	840	1/goat	75	180.55	55
110	Dcst	980	1/zebra	75	195.41	55
110	Dcst	1050	2/wolf	75	223.74	55
110	Dcst	1280	2/goat	50	295.26	55
110	Dcst	1500	2/zebra	50	321.20	55
110	Dcst	1640	1/chukar	75	273.37	55
110	Dcst	1680	2/goat	75	296.05	55
110	Dcst	1960	2/zebra	75	324.84	55
110	Dcp	400	1/wolf	50	97.00	55
110	Dcp	525	1/wolf	75	100.14	55
110	Scst	315	1/hyena	50	91.57	55
110	Sest	360	1/coyote	50	96.61	55
110	Sest	410	1/hyena	75	92.98	55
110	Sest	525	1/wolf	75	104.48	55
110	Sest	640	1/goat	50	128.46	55
110	Scp	315	1/hyena	50	51.41	55
110	Scp	360	1/coyote	50	53.48	55
110	Scp	410	1/hyena	75	53.91	55
110	Scp	525	1/wolf	75	57.02	55
110	Scp	640	1/goat	50	66.05	55
220	Dcst	750	1/zebra	50	210.54	55
220	Dcst	980	1/zebra	75	212.97	55
220	Dcst	1280	2/goat	50	319.92	55
220	Dcst	1500	2/zebra	50	353.41	55
220	Dcst	1640	1/chukar	75	307.03	55
220	Dcst	1680	2/goat	75	324.31	55
220	Dcst	1960	2/zebra	75	362.80	55
220	Dcst	3280	2/chukar	75	538.91	55
220	Sest	640	1/goat	50	132.34	55
220	Sest	750	1/zebra	50	146.96	55
220	Sest	980	1/zebra	75	149.87	55
220	Sest	1280	2/goat	50	210.85	55

**Table A.9: Seismic Adjustment Factors (for Substations)**

<b>Equipment Type</b>	<b>Zone A (high risk)</b>	<b>Zone B (medium risk)</b>	<b>Zone C (low risk)</b>
Establishment	1.14	1.06	1.00
Buildings	1.02	1.01	1.00
Oil Containment	1.14	1.06	1.00
Transformers	1.04	1.02	1.00
Switchgear	1.02	1.01	1.00
Other Plant	1.02	1.01	1.00

**Table A.10: Interest During Construction Factors**

<b>Asset Type</b>	<b>Factor (Annualised Rate)</b>
Substation assets	4.8%
Transmission line assets	4.0%

## **APPENDIX B: OPTIMISATION**

### **Introduction**

B.1 Optimisation of an ELB's system fixed assets shall be undertaken in accordance with the requirements of clauses 2.18-2.47. The general approach is to first determine the appropriate optimisation criteria and then to systematically test the network configuration, network capacity and network engineering against the optimisation criteria. The network is adjusted in an incremental fashion in situations where it is found that a more cost-efficient design will meet the predetermined criteria. This appendix describes the minimum tests that shall be applied in all cases in order to optimise a network in accordance with the requirements of this handbook.

### **Optimisation of Network Configuration**

#### **B.2 Connection/Supply Points**

*Issue:* Whether all existing points of supply are required, given the ELB's disclosed quality of supply criteria.

*Approach:* Location and supply voltage may be considered fixed. All points of supply shall be tested to determine whether a more cost-efficient network would result if the point of supply were eliminated and the load supplied from adjacent points of supply. If possible, the point of supply shall be optimised out and replaced with a notional more cost-efficient network.

#### **B.3 Transmission/Subtransmission/Primary Distribution Circuits**

*Issue:* Whether the number of transmission/subtransmission lines exceeds the number required given the ELB's disclosed quality of supply criteria and allowed future load growth.

*Approach:* The route of each line may be considered fixed. Assess the number of transmission/subtransmission lines in relation to the ELB's disclosed quality of supply criteria and allowed future load growth. Optimise out those that are not required. Furthermore, assess whether the existing voltage is still required or whether the lines could be replaced with a lower voltage network. If possible, the lines shall be optimised out and replaced by a notional lower voltage network.

#### **B.4 Transmission Substations/Zone Substations/Primary Distribution Substations**

*Issue (a):* Whether the number and voltage of substations exceeds that which is required to meet the ELB's disclosed quality of supply criteria and allowed future load growth.

*Approach:* The location of all substations may be considered fixed. Each substation shall be tested to determine whether a more cost-efficient network would result if the substation were eliminated or reduced in voltage. Optimise out assets not required and replace with a notional more cost-efficient network.

*Issue (b):* Whether substation configuration exceeds ELB's requirements.

*Approach:* Review the configuration of each substation, including the need for more than a single busbar. Where the ELB's quality of supply requirements can be met by a more cost-efficient design replace existing configuration with a notional more cost-efficient configuration.

## **B.5 High Voltage Distribution Network**

*Issue (a):* Use of very low capacity or less than three phase distribution lines.

*Approach:* Where the existing distribution line or a part of it is of less than three phase construction, the line shall be valued accordingly. Three phase distribution spur lines in rural areas shall be optimised to single phase two wire lines where there are no existing three phase customers and it is possible to meet the ELB's quality of supply criteria with a two wire arrangement.

*Issue (b):* Valuation of single wire earth return (SWER) circuits.

*Approach:* These systems should be valued as if they were constructed using a light single phase two wire distribution circuit with the isolating transformer optimised out. ELBs may use non-standard replacement costs for single wire systems provided the total replacement cost of the system is less than the standard replacement cost of the equivalent two wire design.

## Transpower

### B.6 Security Guidelines for Transmission Planning<sup>6</sup>

Load (MW)	Basic Security	Transmission Circuits	Busbars	Transformers
Less than 10	n	One circuit	One bus or bus section	1 x 3-phase units.
(10 to 40, if more than 40km remote and local generation can limit load shed to 25%)	n	One circuit	One bus or bus section	4 x 1-phase or 1 x 3-phase unit, if backed up from alternative supply point.
From 10 to 300	n-1	Two circuits	Two busbars or bus sections	7 x 1-phase units or 2 x 3-phase units. Firms supply of peak demand using any short-term overload capability.
More than 300	n-2	Three circuits on at least two routes	One redundant bus or bus section, such that supply is not lost after a single contingency while one bus is out of service for maintenance	7 x 1-phase units or 2 x 3 phase units. Firms supply of peak demand using any short-term overload capacity.
More than 600	Loss of station	Supply into region should be diversified across more than one major terminal substation.		

<sup>6</sup> For use where security requirements are not specified contractually and are not inherent in an investment approved by the Electricity Commission.

## **Optimisation of Network Capacity and Network Engineering**

### **B.7 Transmission/Subtransmission/Primary Distribution Lines and Cables**

*Issue (a):* Conductor and cable size.

*Approach:* Determine the required capacity of the line or cable given the disclosed quality of supply criteria and allowed future load growth. Optimise down the size of the conductor or cable to the most cost-efficient standard size that meets the required capacity utilising the short-term ratings of the conductors or cables as appropriate.

*Issue (b):* Whether underground cables are justified.

*Approach:* Review existing underground transmission, subtransmission and primary distribution cables to determine whether undergrounding is justified. Possible justifications for undergrounding include:

- (i) local authority planning criteria prohibit the construction of new overhead circuits;
- (ii) the use of underground cable is the most cost-efficient means of achieving the disclosed quality of supply criteria;
- (iii) economic analysis shows that underground cable is the most cost-efficient method of providing the required network service;
- (iv) consultation with customers affected (including those affected by having to pay higher electricity distribution prices) has demonstrated a willingness to pay the additional cost of the underground service; or
- (v) the existing underground cable was funded by a capital contribution equal to, as a minimum, the difference in the capital cost of overhead and underground circuits.

If suitable justification for existing underground circuits cannot be provided then optimise the underground circuits to overhead. The justification for retaining underground cable in the optimised network shall be described in general terms in the valuation report.

*Issue (c):* Underground cable trenching.

*Approach:* Optimise the trenching arrangement of existing underground cables. Cables running close together, or on the same side of any road or street shall be optimised to a single trench except where this would not meet the ELB's disclosed quality of supply criteria. Derating factors applicable to cables run in a single trench should be considered when making this assessment. If more than one underground cable is laid in a trench, only the incremental cost of the additional cable(s) may be included in the valuation. Table A.1 provides standard replacement costs for double circuit cables.

## **B.8 Substations/zone/primary distribution substations**

*Issue (a):* Under-utilised equipment installed at substations.

*Approach:* Optimise the size of the equipment used, including transformers, to the lowest standard rating that meets the disclosed quality of supply criteria and allowed future load growth.

*Issue (b):* Land and buildings.

*Approach:* Optimise indoor substations to outdoor where land is available and where this will result in a more cost-efficient design unless there are clear technical reasons or local authority requirements that prevent this.

Optimise out any unutilised or under-utilised land so that the value of the land allowed reflects only the area of land required to meet the ELB's disclosed quality of supply criteria and allowed future load growth.

Reduce the replacement cost of buildings to that of a simple standard modern structure using pre-fabricated or other low cost designs. A higher standard of construction is allowed only where the ELB can provide evidence to show that a lower cost design will not meet local authority planning requirements, given the location of the substation. The size of the optimised design should not exceed that required to meet the essential functionality of the building.

*Issue (c):* Whether substation engineering exceeds ELB requirements.

*Approach:* Review the standard of engineering of each substation. If possible, recent projects undertaken by the ELB should be used as a benchmark for this test. If it is found that a more cost-efficient standard of engineering would meet the ELB's disclosed quality of supply criteria, the existing assets should be notionally re-engineered and the replacement costs reduced accordingly. Compliance with territorial local authority conditions for the substation location should be retained in any notional redesign.

*Issue (d):* Fire protection and oil retention facilities.

*Approach:* Include equipment currently installed unless not required for MEA.

## **B.9 High Voltage Distribution**

*Issue (a):* Conductor and cable size.

*Approach:* Examine thermal ratings, faults and current levels to determine the most cost-efficient conductor size for each feeder, given the disclosed quality of supply criteria and allowed future load growth. Optimise down where necessary.

*Issue (b):* Whether underground cables are justified.

*Approach:* Review existing underground distribution cables to determine whether undergrounding is justified. Possible justifications for undergrounding include:

- (i) local authority planning criteria prohibit the construction of new overhead circuits;
- (ii) the use of underground cable is the most cost-efficient means of achieving the disclosed quality of supply criteria;
- (iii) economic analysis shows that underground cable is the most cost-efficient method of providing the required network service;
- (iv) consultation with customers affected (including those affected by having to pay higher electricity distribution prices) has demonstrated a willingness to pay the additional cost of the underground service; or
- (v) the existing underground cable was funded by a capital contribution equal to, as a minimum, the difference in the capital cost of overhead and underground circuits.

If suitable justification for existing underground circuits cannot be provided then optimise the underground circuits to overhead. The justification for retaining underground cable in the optimised network shall be described in general terms in the valuation report.

*Issue (c):* Underground cable trenching.

*Approach:* Optimise the trenching arrangement of existing underground cables. Cables running close together, or on the same side of any road or street shall be optimised to a single trench except where this would not meet the ELB's disclosed quality of supply criteria. Derating factors applicable to cables run in a single trench should be considered when making this assessment. If more than one underground cable is laid in a trench only the incremental cost of the additional cable(s) may be included in the valuation. Table A.1 provides standard replacement costs for double circuit cables.

## **B.10 Voltage Control Devices**

- Issues:*
- (i) Degree of control
  - (ii) Manual and on-load tap changes
  - (iii) Line regulators and line drop compensation
  - (iv) Reactive compensation.

*Approach:* Test requirements for all existing voltage control devices and optimise out where there is no clear justification for the equipment.

## **B.11 Distribution Transformers (pole, kiosk, ground types)**

*Issue:* Utilisation of transformer capacity.

*Approach:* Optimise out excess distribution transformer capacity so that the capacity utilisation (ratio of current peak load, converted to MVA at an assumed power factor of 0.95, to total distribution transformer capacity) for the network is at a level judged to be efficient for the ELB, given its load and supply characteristics, but in any case not less than 30%. If transformer redundancy is specifically provided for in a customer non-standard contract, an appropriate adjustment may be made prior to calculating network transformer utilisation. Any such adjustments shall be disclosed in the valuation report. Transformer capacity optimised out shall be valued at the average DRC per kVA of the ELB's transformer equipment.

In applying this test, ELBs may separate out segments of the network (zone substations or high voltage feeders) with peak loads that are not coincident with the network peak and apply this test separately to such segments. If this approach is taken, details shall be included in the optimisation description included in the valuation report.

## **B.12 Low Voltage Distribution**

*Issue (a):* Whether underground cables are justified.

*Approach:* Review existing underground low voltage cables to determine whether undergrounding is justified. Possible justifications for undergrounding include:

- (i) local authority planning criteria prohibit the construction of new overhead circuits;
- (ii) the use of underground cable is the most cost-efficient means of achieving the disclosed quality of supply criteria;
- (iii) economic analysis shows that underground cable is the most cost-efficient method of providing the required network service;
- (iv) consultation with customers affected (including those affected by having to pay higher electricity distribution prices) has demonstrated a willingness to pay the additional cost of the underground service; or
- (v) the existing underground cable was funded by a capital contribution equal to, as a minimum, the difference in the capital cost of overhead and underground circuits.

If suitable justification for existing underground circuits cannot be provided then optimise the underground circuits to overhead. The justification for retaining underground cable in the optimised network shall be described in general terms in the valuation report.

*Issue (b):* Underground distribution trenching.

*Approach:* Optimise the trenching arrangement of existing underground cables. Cables running close together, or on the same side of any road or street shall be optimised to a single trench except where this would not meet the ELB's disclosed quality of supply criteria. Derating factors applicable to cables run in a single trench should be considered when making this assessment. If more than one underground cable is laid in a trench only the incremental cost of the additional cable(s) may be included in the valuation. Table A.1 provides standard costs for double circuit low voltage cables.

*Issue (c):* Whether the configuration and engineering of the low voltage distribution network exceeds the standard required to meet the ELB's quality of supply criteria.

*Approach:* Review the standard of engineering of the low voltage distribution network, using recent projects undertaken by the ELB as a benchmark for this test. If it is found that a more cost-effective standard of engineering would meet the ELB's disclosed quality of supply criteria, those parts of the low voltage network containing excess asset value should be notionally reconfigured so that they do not exceed the required standard. Assets that are not required should be optimised out.

In applying this test, it is not required that ELBs examine each individual low voltage circuit. It is acceptable to estimate the proportion of the ELB's low voltage distribution network that is over-engineered and apply an appropriate optimisation factor. However details of the approach taken shall be included in the optimisation description included in the valuation report in accordance with clause 2.65(j).

### **B.13 System Control**

*Issue (a):* Degree of sophistication of SCADA equipment.

*Approach:* Determine whether equipment is appropriate on the basis of disclosed quality of supply criteria. Reduce replacement cost to that of a MEA of the required sophistication.

*Issue (b):* Need for load control system and degree of sophistication.

*Approach:* Determine whether equipment is appropriate for the degree of control required. If necessary, reduce replacement cost to that of a MEA of the required sophistication.